
	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX														
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No <table border="1" style="width: 100%; text-align: center;"> <tr> <th>PHASE</th> <th>AREA</th> <th>TRAIN/ UNIT</th> <th>DIS</th> <th>DOC</th> <th>SEQ</th> <th>REV</th> </tr> <tr> <td>IWPRD</td> <td>01</td> <td>0001</td> <td>EL</td> <td>ST</td> <td>001</td> <td>D1</td> </tr> </table>						PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	IWPRD	01	0001	EL	ST	001	D1
PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV																
IWPRD	01	0001	EL	ST	001	D1																

X MINISTRY OF ENERGY X WATER & POWER RESOURCES DEVELOPMENT CO.

X HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE

DOCUMENT TITLE

CAUSES OF THE DAMAGE

IWPRD-01-0001-EL-ST-001

D1	Jan.2008-01-10						
D0	Nov2007-11-07						
REV	DATE ISSUED	PREPARED	CHECKED	AUTH.	APPROVED		PURPOSE OF ISSUE
0	86.08.16	i	smk@tomcad.com				Issued for Abniroo



**X III HYDRO POWER GENERATION PLANT
UNIT 7 GENERATOR DAMAGE**



XXXXXXXX

Document Title	DOCUMENT No							Page 2 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Page	Revisions							Page	Revisions						
	D0	D1	D2	D3	D4	D5	D6		D0	D1	D2	D3	D4	D5	D6
1	*	*						51	*						
2	*	*						52	*						
3	*							53	*						
4	*							54	*						
5	*							55	*						
6	*	*						56	*						
7	*							57	*						
8	*							58	*						
9	*							59	*						
10	*							60	*						
11	*							61	*						
12	*							62	*						
13	*							63	*						
14	*							64	*						
15	*							65	*	*o					
16	*							66	*						
17	*							67	*	*o					
18	*							68	*						
19	*							69	*	*o					
20	*	*						70	*	*o					
21	*	*						71	*						
22	*							72	*						
23	*							73	*						
24	*							74	*						
25	*							75	*						
26	*							76	*						
27	*							77	*						
28	*							78	*						
29	*	**51						79	*						
30	*							80	*						
31	*							81	*						
32	*							82	*						
33	*							83	*						
34	*							84	*						
35	*							85	*						
36	*							86	*						
37	*							87	*						
38	*							88	*						
39	*							89	*						
40	*							90	*						
41	*							91	*						
42	*							92	*						
43	*							93	*						
44	*							94	*						
45	*							95	*						
46	*							96	*						
47	*							97	*	*n					
48	*							98	*						
49	*							99	*						
50	*							100	*						
101	*	*						121	*	*					





	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 3 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

TABLE OF CONTENTS

Table of Contents

1. INTRODUCTION	6
2. SCOPE.....	6
3. SYSTEM DESCRIPTION AND INPUT DATA	6
3.1 REPORTS AVAILABLE	16
3.2 RECORDS AVAILABLE	16
4. MODELLINGS AND SIMULATION RESULTS.....	20
5. SEQUENCE OF THE EVENTS.....	20
6. CAUSE OF INITIAL SINGLE PHASE FAULT IN PHASE T	22
7. CONCLUSION	23
<i>APPENDIX I.....</i>	<i>24</i>
<i>MANUPULASION OF CURRENT AND VOLTAGES WAVEFORM.....</i>	<i>24</i>
<i>APPENDIX II.....</i>	<i>29</i>
<i>CURRET TRANSFORMER MODELLING</i>	<i>29</i>
APPENDIX III.....	53
SYSTEM FAULT AND LOAD FLOW STUDIES.....	53
APPENDIX IV	70
GENERATOTR MODELLING FOR FIELD TRANSIENTS	70
APPENDIX V	90
FAST TRANSIENT SWITCHING.....	90
APPENDIX VI	93
ARCING GROUND PHENOMENA	93
APPENDIX VII	97

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 4 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

FERRO RESONANCE EFFECTS97

APPENDIX VIII104



GENERATOR WINDING CONNECTION.....104

APPENDIX VIII110

WEATHER CONDITION110



APPENDIX X112

PROTECTION RESPONSE112

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
Document Title	DOCUMENT No							
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 5 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Dedicated to my students in Power System Analysis Lab.

Acknowledgments

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 6 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

1. INTRODUCTION

XIII hydro generation plant is designed to produce more than 2000 MW power generation by its 8 generator units. The generation plant is located near to X Village, about 200 km North East of X city.

At 3:30 afternoon of 27-05-2007, normal operation became suddenly disrupted. According to the operators a huge burning fire has come out from unit no.7. The trip was triggered off by the generator relays according to the event lists.

The purpose of this report is to investigate the possible causes of the faults and the design or operation problems related to the event.

2. SCOPE

The objective of this document is to find out the causes of the events through analysis. In order to investigate the causes of the faults including those related to the operation malfunctions, design problems, protection recovery or tuning problems, studies as described in the followings are performed.

3. SYSTEM DESCRIPTION AND INPUT DATA

Single line diagram as represented in drawing DWG.NO. 12R9-16/E-64-101/D is used to represent the power generation plant inside the simulation program (PASHA). Figure 1 shows the representation of the plant while unit no.7& 8 are represented in details and other units (those which are operating at the instant of the accident) are represented as equivalent generator and transformer (4 other generators and 4 other unit transformers were in service). Xian national grid as viewed from X III entering busbar is represented by an equivalent generator on 400KV incoming busbar.

Final data sheet of the generator (Drwg. No. 5-995.080) is used to provide the generator and its excitation data. Excitation system documentation components (letter no: K3 AG FB A 0494.DOC) is also employed to fulfil the data for the excitation system. Document 1KHF601002 from ABB is used to find out the settings of the protection system REG216. Relay software's Win-eve and HMI are used to find out other protection settings and records. Unit transformer resistance and reactances are extracted from these documents. Those equipment or loads that were not in the category of the studies intended are either ignored or represented by their equivalent.






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure1. The representation of the plant in PASHA simulation program



NETWORK DIAGRAM DRAWING - CLICK ICON FOR TOOLS



COPYRIGHT (C) TOM InC 1988 TIME : 00:20:54 08/11/2007

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
Document Title	DOCUMENT No							Page 8 of 121
CAUSES OF THE DAMAGE	PHASE IWPRD	AREA 01	TRAIN/ UNIT 0001	DIS EL	DOC ST	SEQ 001	REV D1	



The following parameter values are used as input data base and INPUT DATA:

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No PHASE AREA TRAIN/UNIT DIS DOC SEQ REV IWPRD 01 0001 EL ST 001 D1					

CABLES AND LINES DATA BASE

CABLE		PASHA LIB.	RATING MVA	RATING KV	RESISTANCE PU/KM	REACTANCE PU/KM	SUSEPTANCE PU/KM	ZERO SEQUENCE RESISTANCE- PU/KM	ZERO SEQUENCE REACTANCE- PU/KM
SIZE	MANUFACT.								
fictious		15	100	15.75		0.0001			0.0001
	CURLEW	2	100	400	0.00002	0.0002	0.0053	0.0002	0.00063
fictious		16	100	15.75		0.0001	0.0012		0.0001
fictious		2	100	400	100		0.0001		0.0001



Note : RATING MVA IS OBTAINED FROM CABLE CURRENT CAPACITY, RATINGS ARE THE PU BASES

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					Page 10 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

TRANSFORMERS DATA BASE

RATING KVA	U1/U2 KV/KV	CONNECTION TYPE **	PASHA LIB.	RESISTANCE PU	REACTANCE PU	ZERO SEQUENCE		MINTAP	TAP STEP	MAXTAP	RATIO DV	BASE MVA	MANUFACT.
						RESISTANCE PU	REACTANCE PU						
300000	410/15.75	XD11	1	0.008	0.14979	0.008	0.12975	-5	2.5	5	-0.03	300	
1095	0.35/15.75	YD5*	2	0.006	0.06			-5	2.5	5	0	1.095	
1600	15.75/3.3	DX1	3		0.06		0.06	-5	2.5	5	0	1.6	

*DY11=DY5, DY1=DY7, X=Yn

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

GENERATOR DATA BASE

RATED POWER MVA	TYPE	RATED VOLTAGE KV	PASHA LIB.	RESISTANCE PU	REACTANCE PU	ZERO SEQUENCE RESISTANCE- PU	REACTANCE- PU	H (SEC)
263	Saturated*	15.75	7	0.0025	0.892	2780.1**	0.094	
263	unsaturated	15.75	71	0.0025	1.065	2780.1**	0.094	

PASHA LIB.	DIRECT AXIS				Xq	QUADRATURE AXES			
	X'd	r'd	X''d	r''d		X'q	r'q	X''q	r''q
7	0.229	10.8	0.2	0.0415	0.6				
71	0.249	10.8	0.23	0.0415	0.656				

*saturated values are used no poiter reactance has been introduced in program to consider the saturation effect

**0.59 Ohm grounding resistor considered in secondary of a 16/1.73KV / 240V from primary 874.07 Ohm. The P.U. value is 926.7 and the 3*R that is 2780.1 P.U. is represented as zero sequence resistance.



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
Document Title	DOCUMENT No							
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 12 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Figure 2. PASHA/UDEM model of Frequency/Load control loop for hydro turbine. Not required in the analysis performed





	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
Document Title	DOCUMENT No							Page 13 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure 3. PASHA/UDEM model of Automatic voltage regulator and excitation system. Not required in the analysis performed.

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No PHASE AREA TRAIN/UNIT DIS DOC SEQ REV IWRD 01 0001 EL ST 001 D1					

INPUT DATA

OSYSTEM TITLE: X 7,8,E WITH PT
OSTUDY TITLE:

SYSTEM MVA BASE = 100.000

PASHA ACTUAL DYNAMIC FAULT IS ACTIVE

B U S B A R D A T A I N P U T



S Y N C H R O N O U S G E N E R A T O R S

BUSBAR NAME	GENERATION		GENERATOR IMPEDANCES PU				0-C TIME CONST		AREA
	P (MW)	Q (MVAR)	RES R	SYN-X XD	DA-TR-X XD'	DA-ST-X XD''	TDO' (MSEC)	TDO'' (MSEC)	
GEN7	280.00	82.15	0.0010	0.3392	0.0871	0.0760	10800.00	41.50	UN7
GENE	1034.00	156.70	0.0010	0.3392	0.0871	0.0760	10800.00	41.50	UNE
WARNING - TDO' OF FOLLOWING MACHINE MISSING									
NETE	31417.92	16941.90	0.0009	0.0058	0.0058	0.0000	0.00	0.00	UNE
GEN8	280.00	41.98	0.0010	0.3392	0.0871	0.0760	10800.00	41.50	UN8

END OF SYNCHRONOUS MACHINE DATA

S T A T I C L O A D S

BUSBAR NAME	LOAD		INITIAL VOLTAGES			AREA
	P (MW)	Q (MVAR)	MAG (PU)	ANG (DEG)	VNOM. (KV)	
GEN7	0.00	0.00	1.0100	8.251	15.750	UN7
J72	0.00	0.00	1.0099	8.235	15.750	UN7
J73	0.00	0.00	1.0098	8.219	15.750	UN7
J74	0.00	0.00	1.0098	8.203	15.750	UN7
JT7	0.00	0.00	1.0097	8.188	15.750	UN7
NETE	33000.00	17000.00	0.9965	0.000	400.000	UNE
GENE	0.00	0.00	0.9900	7.710	15.750	UNE
JE2	0.00	0.00	0.9899	7.684	15.750	UNE
JE3	0.00	0.00	0.9899	7.676	15.750	UNE
JE4	0.00	0.00	0.9899	7.667	15.750	UNE
F7	0.00	0.00	0.9582	8.528	0.350	UN7
FE	0.00	0.00	0.9899	7.684	0.350	UNE
JTE	0.00	0.00	0.9899	7.658	15.750	UNE
FI7	0.00	0.00	0.6750	8.528	0.280	UN7
D7	0.00	0.00	0.9582	8.528	0.280	D
SE7	0.00	0.00	1.0098	8.219	3.300	UN7
B78	0.00	0.00	0.9968	0.124	400.000	UNE
GEN8	0.00	0.00	0.9900	8.480	15.750	UN8
J82	0.00	0.00	0.9900	8.464	15.750	UN8
J83	0.00	0.00	0.9899	8.448	15.750	UN8
J84	0.00	0.00	0.9899	8.431	15.750	UN8
JT8	0.00	0.00	0.9898	8.415	15.750	UN8
F8	0.00	0.00	0.9392	8.757	0.350	UN8
FI8	0.00	0.00	0.6616	8.757	0.280	UN8
D8	0.00	0.00	0.9392	8.757	0.280	D
SE8	0.00	0.00	0.9899	8.448	3.300	UN8
MAIN00	0.00	0.00	0.9965	0.009	400.000	UNE

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 15 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

```

PT3      0.00  0.00  1.0098  8.219  0.110  PT
PT3A     0.00  0.00  1.0098  8.219  0.110  PT
DELTA    0.00  0.00  1.0098  8.219  0.367  PT
JB78     0.00  0.00  0.9967  0.118  400.000
JJB78    0.00  0.00  0.9965  0.015  400.000

```

END OF STATIC LOAD DATA

INDUCTION MOTORS

BUSBAR NAME	LOAD TYPE PASHA	P (MW)	Q (MVAR)	MOTOR IMPEDANCES PU						MAGNETISING REACT	AREA
				STATOR		ROTOR 1		ROTOR 2			
				RES	REACT	RES	REACT	RES	REACT		



END OF INDUCTION MACHINE DATA

END OF BUSBAR DATA

BRANCH DATA INPUT

BUSBAR FROM	TO	BRANCH IMPEDANCES (PU)						TRANSFORMER TAP WINDING (%)	AREA-TO-AREA CODE	PASHA	TYPE
		PPS AND NPS		ZPS		SUSC					
		R	X	R	X	B					
GEN7	J72	0.0000	0.0001	0.0000	0.0001	0.0012		UN7	UN7	16.	
J72	J73	0.0000	0.0001	0.0000	0.0001	0.0000		UN7	UN7	15.	
J73	J74	0.0000	0.0001	0.0000	0.0001	0.0000		UN7	UN7	15.	
J74	JT7	0.0000	0.0001	0.0000	0.0001	0.0000		UN7	UN7	15.	
GENE	JE2	0.0000	0.0000	0.0000	0.0000	0.0252		UNE	UNE	16.	
JE2	JE3	0.0000	0.0000	0.0000	0.0000	0.0000		UNE	UNE	15.	
JE3	JE4	0.0000	0.0000	0.0000	0.0000	0.0000		UNE	UNE	15.	
J72	F7	0.5479	5.4795	0.0000	0.0000	0.0000	0.0	YD11	UN7	UN7	2.
JE2	FE	0.1370	1.3699	0.0000	0.0000	0.0000	0.0	YD11	UNE	UNE	2.
JE4	JTE	0.0000	0.0000	0.0000	0.0000	0.0000		UNE	UNE	15.	
FI7	FI7	0.0000	71.5000	0.0000	0.0000	0.0000		UN7	UN7	0.	
D7	FI7	0.0000	30.0000	0.0000	0.0000	0.0000		D	UN7	0.	
F7	D7	0.0000	0.0001	0.0000	0.0000	0.0000	0.0		UN7	D	0.
J73	SE7	0.0000	3.7500	0.0000	3.7500	0.0000	0.0	DX1	UN7	UN7	3.
B78	JT7	0.0027	0.0499	0.0027	0.0433	0.0000	0.0	XD11	UNE	UN7	1.
GEN8	J82	0.0000	0.0001	0.0000	0.0001	0.0012			UN8	UN8	16.
J82	J83	0.0000	0.0001	0.0000	0.0001	0.0000			UN8	UN8	15.
J83	J84	0.0000	0.0001	0.0000	0.0001	0.0000			UN8	UN8	15.
J84	JT8	0.0000	0.0001	0.0000	0.0001	0.0000			UN8	UN8	15.
J82	F8	0.5479	5.4795	0.0000	0.0000	0.0000	0.0	YD11	UN8	UN8	2.
FI8	FI8	0.0000	71.5000	0.0000	0.0000	0.0000			UN8	UN8	0.
D8	FI8	0.0000	30.0000	0.0000	0.0000	0.0000			D	UN8	0.
F8	D8	0.0000	0.0001	0.0000	0.0000	0.0000	0.0		UN8	D	0.
NETE	MAIN00	0.0000	0.0000	0.0000	0.0000	0.0000			UNE	UNE	0.
MAIN00	JTE	0.0007	0.0125	0.0007	0.0108	0.0000	0.0	XD11	UNE	UNE	1.
B78	JT8	0.0027	0.0499	0.0027	0.0433	0.0000	0.0	XD11	UNE	UN8	1.
J83	SE8	0.0000	3.7500	0.0000	3.7500	0.0000	0.0	DX1	UN8	UN8	3.
PT3	PT3A	0.0000	0.1000	0.0000	40.0000	0.0000	0.0	DX1	PT	PT	4.
PT3A	J73	0.0000	0.1000	0.0000	0.1000	0.0000	0.0	XX0	PT	UN7	4.
PT3A	DELTA	0.0000	0.1000*****	0.0000	0.0000	0.0000	0.0	XD11	PT	PT	5.
JB78	B78	0.0000	0.0000	0.0000	0.0000	0.0006				UNE	2.
MAIN00	JJB78	0.0000	0.0000	0.0000	0.0000	0.0006			UNE		2.
JJB78	JB78	0.0000	0.0003	0.0003	0.0008	0.0112					2.

END OF BRANCH DATA

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

3.1 REPORTS AVAILABLE

Prior to the start of the studies the following reports about the events were issued and were made available to us at September 2007:

- a) Failure in unit 7 of X generation plant
- b) Report of the event of unit 7 and its causes.
- c) Analysis of the event on unit 7
- d) Technical report about the short circuit fault in unit 7 of the generation plant – In Persian – Issued by Mahab Ghods
- e) Protection relay response during the event – In Persian – Issued by ABBNIRO
- f) Generator damage of 27.05.2007 HEPP X III /Unit 7 description of damage and analysis of possible fault causes – In English- Issued by ANDRITZ VA TECH HYDRO (through Elin)

3.2 RECORDS AVAILABLE

Apart from the drawings and the data sheets of the plant components, the following records and observations are used to provide the conclusions:

- a) A site visit
- b) Event list (table AX.1)
- c) Records of the fault currents and voltages from REG216 (figure 2)
- d) Phase S of the X-Y line surge arrester shows a lightning discharge. The discharge had been happened between 16.1.86 till 12.6.86 (Persian dates)
- e) Phase S of the Unit 8 surge arrester shows three lightning discharges. The discharge had been happened between 15.2.86 till 15.4.86 (Persian dates)
- f) The stator damage pictures (figure 3)
- g) The field damage pictures (figure 4)
- h) Manual records of main data (currents, voltages, etc) of each half hours, written by operators
- i) Test are conducted in Unit no. 8 to tune the record values (because of the error recognized in the measuring devices)
- j) Measurements are conducted to find out some of the component characteristics. They are used in this document as the case will arise.




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 17 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure 2: REG216 records





	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 18 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure 3: Stator damages








	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 19 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure 4: Field damages



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 20 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

4. MODELLINGS AND SIMULATION RESULTS



The following simulation studies are used:

- 1) Appendix I manipulates the three phase instantaneous values of the currents and voltages which are shown in figure 2 (i.e. the only available record of the event) in order to provide some other useful variables such as the active and reactive powers, zero sequence currents, etc, before and during the events. Tables AI.1 and AI.2 show the results obtained. The start time is selected to be -98.4/-98.3 (will be used here as the time zero) and the time interval is 0.1 msec. The formula used to find out the required variables are described in appendix I.
- 2) The same results as the case (1) above, is shown in table AI.2 while CT modelling and its transient response are used to extract the CT errors and to find out the primary currents from the secondary currents. CT model is described in appendix II.
- 3) Load flow studies prior to the fault are described in appendix III.
- 4) Fault studies including intermediate faults inside the generator are performed, in order to find a clear insight into the sequence of the events. These studies are also described in appendix III.
- 5) The transient behaviour of the generator and its field are simulated in appendix IV, in order to find out the overvoltage's which had happened in the field.
- 6) Fast transient switching studies are performed to find out the stator overvoltages. This is described in appendix V.
- 7) Theory and the occurrence of the arcing ground phenomena are described in appendix VI.
- 8) Theory and the occurrence of the Ferro resonance effects are described in appendix VII.
- 9) Generator winding connection, described in appendix VIII.
- 10) Weather condition and lightening possibility is described in appendix VIII.
- 11) Protection event lists are discussed in appendix X.

5. SEQUENCE OF THE EVENTS



The following sequence of the events can be recognized:

- a) The magnitude of the zero sequence currents shown in Table AI.2, suggest that at the time around 96.5 a single phase fault starts to be initiated. Its minus sign indicates that it is in phase T, because it flows at the same direction of the voltage of the phase T. The amount of zero sequence current (3I0) is about $(0.0055 \times 12500 = 69A)$. This is the current which comes from the open delta PT (i.e. PT3) which is in the Ferro resonance mode at the time (please refer to appendix VIII). The single phase fault is located in the slot 217 in the first section (number 1) of the winding 3W, near to the power leads of the generator. This is the time that the 64GB shows the existence of a single phase fault.
- b) Two milliseconds latter at instant of time (-93.6), an overload has been occurred. This is obvious from the power (S) obtained in table 3 that exceeds 302.45MVA. The overload relay 46 shows the occurrence of the event.
- c) At the same instant of time or so, when the single phase fault is well established, the amount of the zero sequence current that comes from the generator would be enough for the 95% earth fault relay to show the

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 21 of 121
	IWPRD	01	0001	EL	ST	001	D1	

occurrence of the single phase fault. No record is available to lead to a direct conclusion of this event, however, the third harmonic must be eliminated by this relay and hence minimum 3.3 msec. delay of this relay can also be reasonable.

- d) The two other phases (R and S) will be separated from the earth and provide a sustained 1.73 P.U. over voltage respect to earth if the single phase fault has enough current to remain. Otherwise the arc will be extinguished (seen at the time -91.7) and the system will restore to the healthy condition. The fluctuation of the zero sequence current till the instant of the two phases fault (-90) is obvious in the table All.1. .Due to the occurrence arcing ground phenomena together with Ferro resonance of the PT3 which are described in the appendices VII, and VIII, all the phases are separated from the ground and they are ready to restrike a second fault to the ground or to the phase which is already grounded. Since there is no record that shows the phase voltages respect to the ground, these over voltages cannot be addressed in table All.1.
- e) At time -90 two phases fault had occurred between phase R in slot (327) and phase T in slot (326), (please refer to appendix III, which proves the existence of this event). At this instant of time the phase R paths its maximum value with respect to the neutral (and so to the earth) as indicated in table All.1 and is ready to flash to the nearest ground potential. If we follow up the winding diagram of the generator or the winding table of the generator, shown in figure VIII.1 and table VIII.1, and consider that winding number 1 of 3W of phase T is grounded through the single phase fault at the slot 217, we can conclude that the first adjacent slots that put these two phases (one in ground potential and the other in the overvoltage mode) near to each other will be the slots 327 and 326, number 9 of 2W and number 18 of 2U. Therefore, a flash over between these windings occurred that imposed a two phase fault. This two phase fault, together with single phase fault that already had existed in winding number 1 of phase T (which is now more weaker because of the occurrence of double phase fault) are the only short circuits that existed in the system until it had been opened by the generator circuit breaker. The existence of the two phase fault has been announced by generator differential relay, and the other generator protection systems, (for more information on item (e) please refer to appendixes III and X).
- f) Generator circuit breaker and the field circuit breaker are ordered to open at the same instant of time. There is no delay for field opening in the emergency mode and its maximum opening time is 60 msec. At time -37 the Controlling diode of the discharging resistor was damaged under the heavy passing current and field overvoltages caused by stator fault, caused a heavy overvoltage in the field which is responsible for all the damages in the field. (Please refer to appendix IV, which describes the field opening). The field circuit breaker might also open around this time and so prevents further huge overvoltage to build up. There are two reasons that the field is short circuited in this instant of time. The first reason is that the voltage waveforms of the phases are disrupted by harmonic currents (the occurrence of the self excitation). The second reason is that the stator phase S current is going to increase after the field opening, due to the reduction of the back EMF voltages in all phases. Phase R current waveform shows a reduction because it was already under fault and phase T current is remained untouched because of the location of the fault in this phase which eliminates the back EMF effect. The situation is shown in the figures of the appendixes. Appendix IV calculates the overvoltage's in the field. Due to these over voltages two flashovers are made their paths to the ground. Figure 4 shows the damages of these faults. The same overvoltage or those which are stem from the stator overvoltage described in sections (i), (j) below, had enough over voltage strength to damage the No 25 field winding and connect it to the earth.
The above discussion is still valid, if the field circuit breaker had been opened latter in time 134msec after the event.
- g) At time -25 GCB opens the incoming phase T. No over voltages can be occurred, since this phase is already grounded in its first winding.
- h) At time -17 GCB opens the remaining two phases. There is no overvoltage in phase S because of the existence of the back EMF in this phase. The situation is not the same for phase R in 2U winding, since

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

about 25% ($18 \times 100 / 72$) of this winding is already earthed though single phase fault of phase T. The back EMF between the power lead and 25% of the winding is very weak and opposes the incoming system EMF because of the fault current direction, therefore not only it does not prevent the occurrence of the subsequent overvoltages but also it contributes to the occurrence of the over voltages that are going to be established in the outgoing part of the 2U winding (other parallel windings in this phase have enough back EMFs).

- i) Opening of phase R produced a very large over voltages in this phase due to the presence of 25% of the remaining inductance and the system capacitance. This is fully described in Appendix V. The frequency is about 14KHZ and the over voltages is more than 55KV. The current of this high frequency oscillation goes through the weak earth fault point in phase T and produce the welding damages that are like an old women hair!
- j) This huge high frequency overvoltage had exploded the partial discharge capacitor of this phase CC2, which can resist only 50KV. It also needs to find a path to the ground to discharge. At the time, there were two grounds available. One in the T phase due to already single phase ground fault which are scattered in the path and the other through DE winding cover (as indicated in the ELIN's report it consist completely of metal). Therefore, a top bar 127 is faulted to the top bar 126 which has also connected to the neutral through earthing transformer. The bottom bar 127 made a path to the DE metal cover and due to its high frequency nature melted the sharp sections of metal cover when arc was established and found its path to the strongest ground point. The scattering of high frequency melting can be seen in the outgoing plates. The high frequency shocks had caused the complete destruction of oil mist distracter and its other belongings.

6. CAUSE OF INITIAL SINGLE PHASE FAULT IN PHASE T

The damages already described in section 5, are all started from a single phase fault in the first winding of 3W of phase T. The objective of this part is to investigate the causes of this event.



There are three possibilities for the initial single phase fault:

- 1- The overheating of the windings
- 2- The overvoltages that stem from ferroresonance effect
- 3- The lightning strike, induced an overvoltage in the generator

The first cannot be proved through simulation.

The second one is possible, because of the losing currents and loose connection of the earthing in PT3 (please refer to appendix VIII). To prove this we need more elaborate simulation analysis, not preceded in this document.

The third one is also possible; please refer to appendix VIII for weather condition. The simulation of this phenomenon is also not preceded in this document.

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 23 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	



7. CONCLUSION

The causes of the intermediate faults inside the generator are discussed. Sections 5 and 6 show the sequence of the events. The followings are the major causes of the events:

- 1) Single phase fault in phase T of stator, is established by either Ferroresonance or lightening or overheating
- 2) Two phase fault has occurred because of arcing ground and ferroresonance
- 3) Field damages have occurred because of overvoltages in the field caused by controlling diodes of discharging resistors and field opening under the fault
- 4) Stator damages are occurred because of faults and overvoltages caused by GCB opening.

The following must just be further investigated:

- 1) The IEEE recommendation for selection of PT must be followed in the design stage of the plant.
- 2) The selection of the earthing resistor
- 3) The arresters in the path leading to generator units
- 4) The Generator Circuit Breaker opening process for the generator internal faults
- 5) The delay for the field opening in case of intermediate fault
- 6) The possibility of arcing ground phenomena occurrence
- 7) Some suggestion about digital recording of the REG216 is made in section AIII.4

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 24 of 121
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX I

MANUPULASION OF CURRENT AND VOLTAGES WAVEFORM

The only available waveform record from the event is the one that is already shown in Figure 2. Table AI.1 shows the current and voltage instantaneous values extracted from this record. The other parameters defined in this table (and the table AII.2 represented in the next appendix) are defined as the followings:

1. P.U. Base

12500A, 15.75KV for line voltages, 15.75/1.73205 for phase voltage quantities

2. Extracted values

CURSOR	Cursor position
Time	Time of the incident. The opening of GCB is the reference.
time	Time of the incident. Start of the graph is the reference.
I _r	Instantaneous value of current of phase R (C.T. ratio 12500:1)
I _s	Instantaneous value of current of phase S (C.T. ratio 12500:1)
I _t	Instantaneous value of current of phase T (C.T. ratio 12500:1)
V _{rs}	Instantaneous value of the voltage between phase R and S on base 110V
V _{st}	Instantaneous value of the voltage between phase S and T on base 110V
V _{tr}	Instantaneous value of the voltage between phase T and R on base 110V



We have been informed that the following three quantities measurements are unreliable, however, their variations seems to be accurate:

I _{fr}	Instantaneous value of A.C current goes to the field phase R (C.T. ratio 100:1)
I _{fs}	Instantaneous value of A.C current goes to the field phase S (C.T. ratio 100:1)
I _{ft}	Instantaneous value of A.C current goes to the field phase T (C.T. ratio 100:1)

3. Calculated values

$$3I_0 = I_r + I_s + I_t$$

3 times of zero sequence current

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 25 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

V_m (P.U.) Instantaneous value of the voltage between phase R and the neutral of generator
Calculation formula = $(V_{rs}-V_{tr}) / 110*1.73205$

V_{sn} Instantaneous value of the voltage between phase S and the neutral of generator
Calculation formula = $(V_{st}-V_{rs}) / 110*1.73205$

V_{tn} Instantaneous value of the voltage between phase T and the neutral of generator
Calculation formula = $(V_{tr}-V_{st}) / 110*1.73205$

$P = (V_m*I_r+V_{sn}*I_s+V_{tn}*I_t)*12.5*15.75/1.73205$ Active power MW. It is constant and valid for the instantaneous values in three phase system in all conditions)

$Q = (V_{rs}*I_t+V_{st}*I_r+V_{tr}*I_s)*12.5*15.75/(1.73205*110)$ Reactive power MVAR. It is just valid for balanced and without harmonic circuits. The approximation is valid for our purposes.

$S = \text{SQRT}(P*P+Q*Q)$ Power generation going to the network. MVA

V_{n0} Neutral voltage respect to earth. This is assumed to be 0 before any single phase fault, and it is 1 P.U. in the present of single phase fault. In case of arcing ground, in theory it can increase to even 6 P.U. Here, it is assumed to be 1 P.U., this is the sustained neutral point voltage in the present of a sustained single phase fault. However, if the exact value is required, it can be calculated during the transient phenomena of arcing ground and ferroresonance described in appendixes VI, VII.

$S_0 = 3I_0*V_{n0}*12.5*15.75/1.73205$ MVA going/coming to/from the earth.

$P_f = (V_m*I_{fr}+V_{sn}*I_{fs}+V_{tn}*I_{ft})*0.001*15.75/1.73205$ Active power of the field MW. It is constant and valid for the instantaneous values in three phase system in all conditions)

$Q_f = (V_{rs}*I_{ft}+V_{st}*I_{fr}+V_{tr}*I_{fs})*0.001*15.75/(1.73205*110)$ Reactive power of the field MVAR. It is just valid for balanced and without harmonic circuits. The approximation is valid for our purposes.

$S_f = \text{SQRT}(P_f*P_f+Q_f*Q_f)$ Field power consumption. MVA

S_t Total MVA produced by generator







	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	Page 26 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Table AI.1 instantaneous values of the recorded data



CURSOR	TIME	I _r	I _s	I _t	V _{rs}	V _{st}	V _{tr}	I _{rf}	I _{sf}	I _{tf}
-984	-98.4	1.123	-0.314	-0.808	63.02	93.68	-158.7	31.57	-12.48	-19.08
-983	-98.3	1.117	-0.303	-0.813	61.4	94.69	-158.1	31.45	-12.16	-19.29
-982	-98.2	1.1	-0.266	-0.83	56.51	97.76	-156.2	31.09	-11.19	-19.9
-981	-98.1	1.081	-0.227	-0.85	51.61	100.8	-154.3	30.72	-10.22	-20.51
-980	-98	1.061	-0.19	-0.87	46.72	103.9	-152.5	30.36	-9.253	-21.12
-979	-97.9	1.041	-0.151	-0.889	41.84	107	-150.6	29.99	-8.282	-21.73
-978	-97.8	1.024	-0.115	-0.906	36.95	110	-148.7	29.63	-7.311	-22.35
-977	-97.7	1.005	-0.075	-0.926	32.06	113.1	-146.8	29.27	-6.343	-22.96
-976	-97.6	0.985	-0.039	-0.945	27.17	116.2	-144.9	28.9	-5.372	-23.57
-975	-97.5	0.968	-0.002	-0.962	22.29	119.2	-143.1	28.54	-4.401	-24.18
-974	-97.4	0.948	0.036	-0.982	17.4	122.3	-141.2	28.18	-3.432	-24.79
-973	-97.3	0.929	0.072	-1.002	12.5	125.4	-139.3	27.81	-2.461	-25.4
-972	-97.2	0.909	0.112	-1.022	7.612	128.5	-137.4	27.45	-1.493	-26.01
-971	-97.1	0.892	0.148	-1.038	2.721	131.5	-135.5	27.08	-0.522	-26.63
-970	-97	0.872	0.188	-1.058	-2.16	134.6	-133.7	26.72	0.446	-27.24
-969	-96.9	0.853	0.224	-1.078	-7.051	137.7	-131.8	26.36	1.417	-27.85
-968	-96.8	0.833	0.263	-1.097	-11.94	140.7	-129.9	25.99	2.388	-28.46
-967	-96.7	0.816	0.3	-1.114	-16.83	143.8	-128	25.63	3.357	-29.07
-966	-96.6	0.788	0.334	-1.123	-21.51	145.3	-124.8	24.99	4.288	-29.37
-965	-96.5	0.755	0.362	-1.123	-26.1	146	-121	24.22	5.203	-29.51
-964	-96.4	0.724	0.392	-1.123	-30.68	146.7	-117.2	23.45	6.115	-29.65
-963	-96.3	0.69	0.421	-1.123	-35.27	147.4	-113.3	22.67	7.03	-29.79
-962	-96.2	0.659	0.451	-1.123	-39.85	148.2	-109.5	21.9	7.943	-29.93
-961	-96.1	0.625	0.479	-1.123	-44.44	148.9	-105.7	21.12	8.858	-30.07
-960	-96	0.595	0.51	-1.123	-49.02	149.6	-101.9	20.35	9.77	-30.21
-959	-95.9	0.561	0.538	-1.123	-53.6	150.3	-98.02	19.58	10.68	-30.35
-958	-95.8	0.53	0.569	-1.123	-58.19	151	-94.19	18.81	11.6	-30.49
-957	-95.7	0.496	0.6	-1.123	-62.77	151.7	-90.35	18.03	12.5	-30.63
-956	-95.6	0.465	0.628	-1.123	-67.36	152.4	-86.52	17.26	13.42	-30.77
-955	-95.5	0.432	0.659	-1.123	-71.94	153.1	-82.69	16.49	14.34	-30.91
-954	-95.4	0.401	0.687	-1.123	-76.53	153.8	-78.86	15.71	15.25	-31.05
-953	-95.3	0.367	0.718	-1.123	-81.11	154.6	-75.02	14.94	16.16	-31.19
-952	-95.2	0.336	0.746	-1.123	-85.7	155.3	-71.19	14.17	17.08	-31.33
-951	-95.1	0.303	0.777	-1.123	-90.28	156	-67.36	13.39	17.99	-31.47

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 27 of 121
	IWPRD	01	0001	EL	ST	001	D1	

-950	-95	0.272	0.805	-1.123	-94.85	156.7	-63.54	12.62	18.9	-31.61
-949	-94.9	0.232	0.827	-1.109	-97.97	154.8	-58.57	11.64	19.51	-31.25
-948	-94.8	0.196	0.85	-1.092	-101.1	153	-53.62	10.67	20.12	-30.87
-947	-94.7	0.157	0.872	-1.075	-104.2	151.1	-48.65	9.694	20.72	-30.51
-946	-94.6	0.12	0.892	-1.058	-107.3	149.3	-43.69	8.717	21.33	-30.14
-945	-94.5	0.081	0.914	-1.044	-110.4	147.4	-38.73	7.743	21.93	-29.77
-944	-94.4	0.044	0.937	-1.027	-113.5	145.5	-33.77	6.767	22.54	-29.4
-943	-94.3	0.005	0.957	-1.01	-116.6	143.7	-28.81	5.793	23.15	-29.03
-942	-94.2	-0.03	0.979	-0.993	-119.7	141.8	-23.85	4.816	23.75	-28.66
-941	-94.1	-0.067	1.002	-0.979	-122.8	140	-18.89	2.866	24.96	-27.92
-940	-94	-0.106	1.022	-0.962	-126	138.1	-13.93	1.892	25.57	-27.55
-939	-93.9	-0.143	1.044	-0.945	-129.1	136.2	-8.968	0.914	26.18	-27.18
-938	-93.8	-0.182	1.066	-0.929	-132.2	134.4	-4.013	-0.058	26.78	-26.82
-937	-93.7	-0.218	1.086	-0.914	-135.3	132.5	0.952	-1.036	27.39	-26.45
-936	-93.6	-0.258	1.109	-0.898	-138.4	130.7	5.908	-2.009	28	-26.08
-935	-93.5	-0.294	1.131	-0.881	-141.5	128.8	10.87	-2.986	28.6	-25.71
-934	-93.4	-0.334	1.151	-0.864	-144.6	126.9	15.83	-3.943	29.05	-25.2
-933	-93.3	-0.367	1.168	-0.844	-146.9	124.4	20.65	-4.861	29.19	-24.43
-932	-93.2	-0.398	1.168	-0.811	-147.7	120.6	25.17	-5.779	29.33	-23.65
-931	-93.1	-0.426	1.168	-0.78	-148.4	116.8	29.69	-6.699	29.47	-22.88
-930	-93	-0.457	1.168	-0.746	-149.1	113	34.21	-7.617	29.61	-22.1
-929	-92.9	-0.485	1.168	-0.715	-149.9	109.2	38.74	-8.535	29.76	-21.32
-928	-92.8	-0.516	1.168	-0.682	-150.6	105.4	43.26	-9.455	29.9	-20.55
-927	-92.7	-0.544	1.168	-0.651	-151.3	101.6	47.78	-10.37	30.04	-19.77
-926	-92.6	-0.575	1.168	-0.617	-152.1	97.83	52.3	-11.29	30.17	-19
-925	-92.5	-0.603	1.168	-0.586	-152.8	94.03	56.82	-12.21	30.31	-18.22
-924	-92.4	-0.634	1.168	-0.552	-153.5	90.22	61.35	-13.13	30.45	-17.45
-923	-92.3	-0.665	1.168	-0.519	-154.3	86.42	65.88	-14.05	30.59	-16.67
-922	-92.2	-0.693	1.168	-0.488	-155	82.61	70.4	-14.97	30.73	-15.89
-921	-92.1	-0.724	1.168	-0.454	-155.7	78.81	74.92	-15.89	30.87	-15.12
-920	-92	-0.752	1.168	-0.423	-156.5	75.01	79.44	-16.81	31.02	-14.34
-919	-91.9	-0.783	1.168	-0.39	-157.2	71.21	83.97	-17.72	31.16	-13.56
-918	-91.8	-0.811	1.168	-0.359	-157.9	67.41	88.49	-18.64	31.3	-12.79
-917	-91.7	-0.842	1.168	-0.325	-158.6	63.61	93.01	-19.36	31.11	-11.88
-916	-91.6	-0.864	1.156	-0.291	-157.7	59.09	96.57	-19.97	30.74	-10.9
-915	-91.5	-0.884	1.137	-0.258	-155.8	54.22	99.65	-20.59	30.38	-9.921
-914	-91.4	-0.9	1.12	-0.221	-153.9	49.34	102.7	-21.2	30.02	-8.945
-913	-91.3	-0.92	1.1	-0.188	-152	44.46	105.8	-21.82	29.66	-7.965

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 28 of 121
	IWPRD	01	0001	EL	ST	001	D1	

-912	-91.2	-0.94	1.081	-0.151	-150.2	39.58	108.9	-22.43	29.3	-6.988
-911	-91.1	-0.959	1.061	-0.117	-148.3	34.7	112	-23.04	28.94	-6.009
-910	-91	-0.976	1.044	-0.081	-146.4	29.82	115.1	-23.66	28.58	-5.032
-909	-90.9	-0.996	1.024	-0.047	-144.6	24.94	118.1	-24.27	28.22	-4.053
-908	-90.8	-1.016	1.005	-0.011	-142.7	20.06	121.2	-24.89	27.86	-3.076
-907	-90.7	-1.033	0.987	0.022	-140.8	15.18	124.3	-25.5	27.49	-2.097
-906	-90.6	-1.052	0.968	0.058	-139	10.3	127.4	-26.12	27.13	-1.12
-905	-90.5	-1.072	0.948	0.092	-137.1	5.431	130.4	-26.73	26.77	-0.14
-904	-90.4	-1.092	0.929	0.129	-135.2	0.55	133.5	-27.34	26.41	0.836
-903	-90.3	-1.109	0.912	0.162	-133.3	-4.33	136.6	-27.96	26.05	1.816
-902	-90.2	-1.128	0.892	0.199	-131.5	-9.211	139.7	-28.57	25.69	2.793
-901	-90.1	-1.148	0.872	0.232	-129.6	-14.09	142.8	-29.19	25.33	3.769
-900	-90	-1.165	0.856	0.266	-127.7	-18.96	145.8	-29.3	24.58	4.634
-899	-89.9	-1.168	0.822	0.3	-122.2	-21.96	143.3	-29.42	23.84	5.495
-898	-89.8	-1.168	0.788	0.334	-116.7	-24.94	140.7	-29.53	23.09	6.357
-897	-89.7	-1.168	0.757	0.364	-111.2	-27.93	138.1	-29.65	22.34	7.218
-896	-89.6	-1.168	0.724	0.398	-105.7	-30.92	135.6	-29.77	21.6	8.08
-895	-89.5	-1.168	0.693	0.429	-100.2	-33.91	133	-29.88	20.85	8.945
-894	-89.4	-1.168	0.659	0.463	-94.74	-36.9	130.4	-30	20.1	9.806
-893	-89.3	-1.168	0.628	0.494	-89.24	-39.88	127.9	-30.11	19.36	10.67
-892	-89.2	-1.168	0.595	0.527	-83.75	-42.87	125.3	-30.23	18.61	11.53
-891	-89.1	-1.168	0.564	0.558	-78.24	-45.87	122.7	-30.34	17.86	12.39
-890	-89	-1.168	0.53	0.592	-72.75	-48.85	120.1	-30.46	17.12	13.26
-889	-88.9	-1.168	0.499	0.623	-67.25	-51.84	117.6	-30.58	16.37	14.12
-888	-88.8	-1.168	0.465	0.656	-61.75	-54.82	115	-30.69	15.63	14.98
-887	-88.7	-1.168	0.435	0.687	-56.25	-57.82	112.4	-30.81	14.88	15.84
-886	-88.6	-1.168	0.401	0.721	-50.75	-60.8	109.9	-30.93	14.13	16.7
-885	-88.5	-1.168	0.37	0.752	-45.25	-63.79	107.3	-31.04	13.39	17.57
-884	-88.4	-1.168	0.336	0.758	-39.76	-66.78	104.7	-30.98	12.58	18.3
-883	-88.3	-1.142	0.303	0.797	-34.14	-69.49	101.8	-30.55	11.68	18.79
-882	-88.2	-1.061	0.261	0.755	-28.3	-71.61	98.07	-30.13	10.76	19.27
-881	-88.1	-0.979	0.221	0.715	-22.45	-73.75	94.37	-29.7	9.845	19.76
-880	-88	-0.9	0.182	0.676	-16.61	-75.88	90.67	-29.28	8.942	20.24

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX II

CURRENT TRANSFORMER MODELLING

We have decided to use 3I0, which is extracted from the current waveforms, to predict the presence of single phase fault. The CT and A/D convertors errors will affect such a decision and therefore we need to model the current transformers. So, the objective of this section is to eliminate the errors of the CTs (12500:1) through modelling.

AII. 1. SOURCE OF ERRORS

There are two kinds of errors. The inherent ratio and phase errors exist in the CT of each phase (phases R, S, T) and the ratio difference error which affects the summation of the three CTs currents.

AII. 2. CT TRANSIENT MODEL

The objective in here is to find out the primary current of each CT from its secondary current. Saturation of the electromagnetic core is the major factor that influences the current transformer transient response. It is caused by non-linear nature of the electromagnetic core of the current transformer. Saturation can lead to sever signal distortions in the current transformer output, if the primary current is too high. It can be represented using V-I characteristic of the core. The V-I characteristic of our CT tested by the manufacturer is shown in Figure AII.1. The errors measured by the manufacture are also shown in this figure. The characteristic presents dependency of exciting voltage V to the exciting current Ie. This dependence is actually the input-output characteristics of a non-linear inductor that can be used to model the electromagnetic core. The model of the CT with its core is shown in Figure AII.2.

The following equations are used to provide the block diagram transfer function of the model shown in figure AII.3:



$$I_e = I_{e1_x} + I_{e2}$$

$$I_p = I_s + I_e$$

$$V = Rm I_{e1_x} = dLm I_{e2_x} / dt = I_{e2_x} dLm / dt + Lm dI_{e2_x} / dt$$

$$dLm / dt = dLm / dV * dV / dt$$

$$V = (Rb + Rc) I_s + (Lb + Lc) dI_s / dt$$

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							
CAUSES OF THE DAMAGE	PHASE IWPRD	AREA 01	TRAIN/ UNIT 0001	DIS EL	DOC ST	SEQ 001	REV D1	Page 30 of 121

From these equations and knowing the values of the $I_s(t)$, the $I_e(t)$ and the $I_p(t)$ can be found. Block diagram transfer function shown in Figure All. 3. I_s is used to find the primary current. The L_m and $d L_m / dV$ are read from the V-I characteristics of the CT.



**X III HYDRO POWER GENERATION PLANT
UNIT 7 GENERATOR DAMAGE**



XXXXXXXX

Document Title	DOCUMENT No							Page 31 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure All.1 Manufacturer characteristics for 12500:1 current transformer

FROM : KIRANCSITE FRK NO. : 186925231978 Aug. 05 2008 03:06PM P1

PFIFFNER

Fehlerbestimmung **Determination of errors**

Typ/ Type: JKQ 940 C Komm. No.: 1999.0065.01 Seite/ Page: 2

Serie Serial No.	Kern Core No.	Übersetzung / Ratio I prim. [A]	I sec. [A]	S [VA]	cos φ	I sec [%]	Grenzen/ Limits [%] [min]		Fehler/ Error [%] [min]	
1	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+1
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+1
2	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.07	+1
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.07	+2
3	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+2
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+2
4	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	0.00	+1
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.07	+2
5	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.04	+2
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+2
6	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.07	+2
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+1
7	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+2
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.07	+2
8	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+2
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+2
9	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.05	+1
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+2
10	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.05	+1
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	+0.18	+1
11	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+1
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.06	+2
12	1	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.05	+1
	2	12500	1.0	30.00	0.80	100	± 1.00	± 60	-0.05	+1

Form 300 10 September 1999



**X III HYDRO POWER GENERATION PLANT
UNIT 7 GENERATOR DAMAGE**




XXXXXXXX

Document Title	DOCUMENT No							Page 32 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

PIFFNER

PROTOKOLL / PROTOCOLE / CERTIFICATE No.1999.0065.01/A
 Mag.Kurve / Courbe de magnétisation / Magnetization curve
 Datum/Date: 26. 7.1999 Freq.: 50.00 Hz Kern/Moyau/Core no.1
 Seite Page 3



Ipr/Isec	Rct 75°C Ohm	Bürde Charge Burden VA	Klasse Classe Class	U U U V	I verlangt I demandé I required A	I gemessen I mesuré I measured A	Res. Rés. Res.
12500/1	39.3	30	5P 20	1316	< 1.00	0.009	O.K.



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE IWPRD	AREA 01	TRAIN/ UNIT 0001	DIS EL	DOC ST	SEQ 001	REV D1	

Figure All.2 CT model







Figure All.3 the block diagram transfer function model

CT MODEL 5P20 30VA,0.8,RS=39.3,XS+XB=0.1855*W ID : CTM6



COPYRIGHT (C) TOM InC 1988 TIME : 22:12:25 28/11/2007

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 34 of 121
	IWPRD	01	0001	EL	ST	001	D1	

AII. 2.1. TESTING THE CT MODEL

The CT model is checked, for the situation tested by the manufacturer (30VA, 0.8 power factor burdens). The errors obtained are listed in table AII.1 shows the validation of the model. Figure AII.4 shows the transient response of the CT error when applying 20 times of the nominal current.

Table AII.1

CT error when applying $1.41 \sin(\omega t) = 0.07 = 0.06\%$
CT error when applying $28.2 \sin(\omega t) = 141.6 = 5\%$

AII. 2.2. USING THE CT MODEL TO OBTAIN THE PRIMARY CURRENTS

The actual burden of our CT is measured to be:



0.44 V in 0.771 A.

The CT model has changed for the new burdens; a typical reactance is used for the burden (it has no much effect in the result). The measured currents as represented in Table I.1 are injected to the CT model. In order to initialize the model, a sinusoidal current for a period of about 0.2 sec as the delay time was injected to the model before injecting the measured values. The delay time is configured to match to the initial value of the measured current.

Figure AII.5 shows the block diagram transfer function form of the model. The measured currents in Table I.1 were injected to the model as described in the above, and the outputs are represented in Table AII.2. For the definition of the variables, please refer to appendix I.

AII. 3. CTs difference error

The zero sequence current has been calculated using the residual currents from three current transformers (one per phase). This is not ideal since high phase currents may cause unequal saturation of the current transformers or unequal ratio errors and produce a false residual current calculated value. In our case the zero sequence current of the unfaulted system is important and during this region of the operation the current is in normal mode before two phases fault. To be insuring about this, a test has been made for unit 8 and the currents are recorded in a normal mode of operation. The CT modelling discussed above has applied and it has been found that the zero sequence currents are in the order of 12A, which is the error of recording digit numbers. During the meeting of 6th of Jan. 2008, one of the respected audience (Dr. Akbari) subject that there are another source of error and

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 35 of 121
	IWPRD	01	0001	EL	ST	001	D1	

that would be A/D convertor digitizer error. With regard to his comments the following section treated in the revision D1 of this document is provided.

All. 4. A/D convertor error

The following are selected from REG216 manual.

a)

Processing unit 216VC62a

- 32 bit processor type 80486DX-2
- Application software on Flash EPROM
- Operating data on RAM
- Settings on non-volatile Flash EPROM
- Potential-free RS-423 interface for PC operation
- Connection to the station control with transmission of messages
- Time clock synchronizing for time-tagging of events
- Non-volatile event and disturbance memory (gold capacitor buffered)
- Space requirement: two rack divisions



Analogue Input unit 216EA61b

- 24 inputs sampled simultaneously in groups of six
- Sampling frequency 600 (720) Hz for a power frequency of 50 (60) Hz
- Space requirement: two rack divisions

b)

All the REG216 protection functions operate with sampled primary system voltages and currents. The sampling rate of the analogue input units is 12 times per period at rated power system frequency with a dynamic range of 15 bits.

All further signal processing takes place digitally. The protection functions are therefore universally applicable, highly accurate and have excellent long-time stability.

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 36 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

c)

Table 35: Disturbance recorder

<ul style="list-style-type: none"> • Max. 12 c.t./v.t. channels • Max. 16 binary channels • Max. 12 analogue channels of internal measurement values • 12 samples per period (sampling frequency 600 or 720 Hz at a rated frequency of 50/60 Hz) • Available recording time for 9 c.t./v.t.- and 8 binary signals approximately 5 s • Recording initiated by any binary signal, e.g. the general trip signal. 	
Data format	EVE
Dynamic range	$70 \times I_N, 2.2 \times U_N$
Resolution	12 bits
Settings:	
Recording periods	
Pre-event	40...400 ms in steps of 20 ms
Event	100...3000 ms in steps of 50 ms
Post-event	40...400 ms in steps of 20 ms

The followings are selected from Win-Eve software station records,

d)



Station ✕

Station Address: 1


Station Name:

Recording Station: ▼

Source Transducers:
 $I_{full} = I_{rated} * 33.053 * \sqrt{2}$
 $U_{full} = U_{rated} * 1.8309 * \sqrt{2}$

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No					
	PHASE IWPRD	AREA 01	TRAIN/ UNIT 0001	DIS EL	DOC ST	SEQ 001	REV D1	

f)





According to the above, the full scale of the digital record is 89.91A, pick. If the recorder would use 15 bits this have enforce $89.81 * 2 / 32767 = 0.0055A$ error on secondary.

However, according to the manual (section c above) disturbance recorder uses just 12 bits from the 15 bits available! for the recording purposes and this will bring :

$89.81 * 2 / 4095 = 0.04386A$ error on secondary. The error is too high and can eliminate the CTs and any other source of errors!! Another drawback of this error is in the Win-Eve software from ABB that is how it reports its values with three decimal digits if the errors are in the order of 0.044IN! Finally the setting of full scale at 89.81 is selected too high.

The above discussion brings the sub-conclusion of section AII.3 .of revision D0 of this report (“Therefore, we reached to the conclusion that no difference error is presented in our calculations, at least before two phases fault”), under question and this may not be true as Dr. Akbari suggested. However, it also show that it might be existed a single phase fault that its current magnitude values are lost in the errors that are just mentioned. From the waveforms we can reach that the measurements are taken place in the times: -98.1 -96.5 -94.9 -93.3 -91.7 -90.1 -88.5. Omitting the maximum assumed A/D convertor errors in these regions will change Table AI.1 as that is shown in table AII.3. This indicates that there would be some differences, which emphasis that the 310 has been lost inside the error margins; otherwise the exact zero would be expected.

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 38 of 121
	IWPRD	01	0001	EL	ST	001	D1	

The discussion in this section must be further followed by a group of digital computing experts, which opens the actual record files in 12 digit format and further helps to find the actual situation.

However, the process discussed in the sequence of the events (section 5 of this report) is still valid for damages occurred in unit 7 for the following reasons:

- 1- There is no doubt that the primary two phase fault is between slot 326 and 327 as shown in Appendix III.
- 2- This fault has occurred because of overvoltage
- 3- The overvoltage must be due to single phase fault with the arcing ground phenomenon, as 64GB relay announced it before differential relay announcements. A/D errors cannot omit this possibility.
- 4- Ferroresonance must had been occurred, because of the damage occurred in PT3 as shown in Appendix V.




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX														
	Document Title CAUSES OF THE DAMAGE	DOCUMENT No <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 12.5%;">PHASE</th> <th style="width: 12.5%;">AREA</th> <th style="width: 12.5%;">TRAIN/ UNIT</th> <th style="width: 12.5%;">DIS</th> <th style="width: 12.5%;">DOC</th> <th style="width: 12.5%;">SEQ</th> <th style="width: 12.5%;">REV</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">IWPRD</td> <td style="text-align: center;">01</td> <td style="text-align: center;">0001</td> <td style="text-align: center;">EL</td> <td style="text-align: center;">ST</td> <td style="text-align: center;">001</td> <td style="text-align: center;">D1</td> </tr> </tbody> </table>							PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	IWPRD	01	0001	EL	ST	001	D1
PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV																
IWPRD	01	0001	EL	ST	001	D1																

Figure All.4 Checking CT error in 20 times of nominal current, 100*Ie

UDEM PLOT OF ELEMENT OUTPUTS IN (%) Scale 141.6



COPYRIGHT (C) TOM InC 1988 TIME : 22:32:51 28/11/2007







	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Table All.2 instantaneous values of the measured data, CT model used to omit the errors

CURSOR	TIME	Ir	Is	It	Ir+Is+It	Vrs	Vst	Vtr	Vrs+Vst+Vtr	time (msec)	Vrn (p.u.)	Vsn(p.u.)	Vtn(p.u.)
-984	-98.4	1.123	0.314	-0.808	0.001	63.02	93.68	-158.7	-2	0	1.164	0.161	-1.325
-983	-98.3	1.117	0.303	-0.813	0.001	61.4	94.69	-158.1	-2.01	0.1	1.152	0.175	-1.327
-982	-98.2	1.100	0.266	-0.830	0.005	56.51	97.76	-156.2	-1.93	0.2	1.116	0.217	-1.333
-981	-98.1	1.081	0.227	-0.850	0.004	51.61	100.8	-154.3	-1.89	0.3	1.081	0.258	-1.339
-980	-98	1.061	0.190	-0.870	0.001	46.72	103.9	-152.5	-1.88	0.4	1.046	0.300	-1.346
-979	-97.9	1.041	0.151	-0.889	0.001	41.84	107	-150.6	-1.76	0.5	1.010	0.342	-1.352
-978	-97.8	1.024	0.115	-0.906	0.004	36.95	110	-148.7	-1.75	0.6	0.974	0.383	-1.358
-977	-97.7	1.005	0.075	-0.926	0.005	32.06	113.1	-146.8	-1.64	0.7	0.939	0.425	-1.364
-976	-97.6	0.985	0.039	-0.945	0.001	27.17	116.2	-144.9	-1.53	0.8	0.903	0.467	-1.370
-975	-97.5	0.968	0.002	-0.962	0.005	22.29	119.2	-143.1	-1.61	0.9	0.868	0.509	-1.377
-974	-97.4	0.948	0.036	-0.982	0.002	17.4	122.3	-141.2	-1.5	1	0.832	0.551	-1.383
-973	-97.3	0.929	0.072	-1.002	0.000	12.5	125.4	-139.3	-1.4	1.1	0.797	0.593	-1.389
-972	-97.2	0.909	0.112	-1.022	0.000	7.612	128.5	-137.4	-1.288	1.2	0.761	0.634	-1.396
-971	-97.1	0.892	0.148	-1.038	0.002	2.721	131.5	-135.5	-1.279	1.3	0.725	0.676	-1.401
-970	-97	0.872	0.188	-1.058	0.002	-2.16	134.6	-133.7	-1.26	1.4	0.690	0.718	-1.408
-969	-96.9	0.853	0.224	-1.078	-0.001	-7.051	137.7	-131.8	-1.151	1.5	0.655	0.760	-1.415
-968	-96.8	0.833	0.263	-1.097	-0.001	-11.94	140.7	-129.9	-1.14	1.6	0.619	0.801	-1.420
-967	-96.7	0.816	0.300	-1.114	0.002	-16.83	143.8	-128	-1.03	1.7	0.583	0.843	-1.427
-966	-96.6	0.788	0.334	-1.123	0.000	-21.51	145.3	-124.8	-1.01	1.8	0.542	0.876	-1.418
-965	-96.5	0.755	0.362	-1.123	-0.006	-26.1	146	-121	-1.1	1.9	0.498	0.903	-1.401
-964	-96.4	0.724	0.392	-1.123	-0.007	-30.68	146.7	-117.2	-1.18	2	0.454	0.931	-1.385
-963	-96.3	0.690	0.421	-1.123	-0.012	-35.27	147.4	-113.3	-1.17	2.1	0.410	0.959	-1.368
-962	-96.2	0.659	0.451	-1.123	-0.013	-39.85	148.2	-109.5	-1.15	2.2	0.366	0.987	-1.353
-961	-96.1	0.625	0.479	-1.123	-0.019	-44.44	148.9	-105.7	-1.24	2.3	0.322	1.015	-1.336
-960	-96	0.595	0.510	-1.123	-0.017	-49.02	149.6	-101.9	-1.32	2.4	0.278	1.042	-1.320
-959	-95.9	0.561	0.538	-1.123	-0.024	-53.6	150.3	-98.02	-1.32	2.5	0.233	1.070	-1.303
-958	-95.8	0.530	0.569	-1.123	-0.023	-58.19	151	-94.19	-1.38	2.6	0.189	1.098	-1.287
-957	-95.7	0.496	0.600	-1.123	-0.027	-62.77	151.7	-90.35	-1.42	2.7	0.145	1.126	-1.270
-956	-95.6	0.465	0.628	-1.123	-0.029	-67.36	152.4	-86.52	-1.48	2.8	0.101	1.153	-1.254
-955	-95.5	0.432	0.659	-1.123	-0.032	-71.94	153.1	-82.69	-1.53	2.9	0.056	1.181	-1.238
-954	-95.4	0.401	0.687	-1.123	-0.035	-76.53	153.8	-78.86	-1.59	3	0.012	1.209	-1.221
-953	-95.3	0.367	0.718	-1.123	-0.038	-81.11	154.6	-75.02	-1.53	3.1	-0.032	1.237	-1.205
-952	-95.2	0.336	0.746	-1.123	-0.041	-85.7	155.3	-71.19	-1.59	3.2	-0.076	1.265	-1.189

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 42 of 121
	IWPRD	01	0001	EL	ST	001	D1	

-951	-95.1	0.303	0.777	-1.123	-0.043	-90.28	156	-67.36	-1.64	3.3	-0.120	1.293	-1.172
-950	-95	0.272	0.805	-1.123	-0.046	-94.85	156.7	-63.54	-1.69	3.4	-0.164	1.320	-1.156
-949	-94.9	0.232	0.827	-1.109	-0.049	-97.97	154.8	-58.57	-1.74	3.5	-0.207	1.327	-1.120
-948	-94.8	0.196	0.850	-1.092	-0.046	-101.1	153	-53.62	-1.72	3.6	-0.249	1.334	-1.084
-947	-94.7	0.157	0.872	-1.075	-0.046	-104.2	151.1	-48.65	-1.75	3.7	-0.292	1.340	-1.048
-946	-94.6	0.120	0.892	-1.058	-0.046	-107.3	149.3	-43.69	-1.69	3.8	-0.334	1.347	-1.013
-945	-94.5	0.081	0.914	-1.044	-0.049	-110.4	147.4	-38.73	-1.73	3.9	-0.376	1.353	-0.977
-944	-94.4	0.044	0.937	-1.027	-0.046	-113.5	145.5	-33.77	-1.77	4	-0.418	1.359	-0.941
-943	-94.3	0.005	0.957	-1.010	-0.048	-116.6	143.7	-28.81	-1.71	4.1	-0.461	1.366	-0.905
-942	-94.2	-0.030	0.979	-0.993	-0.044	-119.7	141.8	-23.85	-1.75	4.2	-0.503	1.373	-0.869
-941	-94.1	-0.067	1.002	-0.979	-0.044	-122.8	140	-18.89	-1.69	4.3	-0.545	1.379	-0.834
-940	-94	-0.106	1.022	-0.962	-0.046	-126	138.1	-13.93	-1.83	4.4	-0.588	1.386	-0.798
-939	-93.9	-0.143	1.044	-0.945	-0.044	-129.1	136.2	-8.968	-1.868	4.5	-0.631	1.392	-0.762
-938	-93.8	-0.182	1.066	-0.929	-0.045	-132.2	134.4	-4.013	-1.813	4.6	-0.673	1.399	-0.726
-937	-93.7	-0.218	1.086	-0.914	-0.046	-135.3	132.5	0.952	-1.848	4.7	-0.715	1.406	-0.690
-936	-93.6	-0.258	1.109	-0.898	-0.047	-138.4	130.7	5.908	-1.792	4.8	-0.757	1.412	-0.655
-935	-93.5	-0.294	1.131	-0.881	-0.044	-141.5	128.8	10.87	-1.83	4.9	-0.800	1.419	-0.619
-934	-93.4	-0.334	1.151	-0.864	-0.047	-144.6	126.9	15.83	-1.87	5	-0.842	1.425	-0.583
-933	-93.3	-0.367	1.168	-0.844	-0.043	-146.9	124.4	20.65	-1.85	5.1	-0.879	1.424	-0.545
-932	-93.2	-0.398	1.168	-0.811	-0.041	-147.7	120.6	25.17	-1.93	5.2	-0.907	1.408	-0.501
-931	-93.1	-0.426	1.168	-0.780	-0.038	-148.4	116.8	29.69	-1.91	5.3	-0.935	1.392	-0.457
-930	-93	-0.457	1.168	-0.746	-0.035	-149.1	113	34.21	-1.89	5.4	-0.962	1.376	-0.414
-929	-92.9	-0.485	1.168	-0.715	-0.032	-149.9	109.2	38.74	-1.96	5.5	-0.990	1.360	-0.370
-928	-92.8	-0.516	1.168	-0.682	-0.030	-150.6	105.4	43.26	-1.94	5.6	-1.018	1.344	-0.326
-927	-92.7	-0.544	1.168	-0.651	-0.027	-151.3	101.6	47.78	-1.92	5.7	-1.045	1.327	-0.282
-926	-92.6	-0.575	1.168	-0.617	-0.024	-152.1	97.83	52.3	-1.97	5.8	-1.073	1.312	-0.239
-925	-92.5	-0.603	1.168	-0.586	-0.021	-152.8	94.03	56.82	-1.95	5.9	-1.100	1.296	-0.195
-924	-92.4	-0.634	1.168	-0.552	-0.018	-153.5	90.22	61.35	-1.93	6	-1.128	1.279	-0.152
-923	-92.3	-0.665	1.168	-0.519	-0.016	-154.3	86.42	65.88	-2	6.1	-1.156	1.263	-0.108
-922	-92.2	-0.693	1.168	-0.488	-0.013	-155	82.61	70.4	-1.99	6.2	-1.183	1.247	-0.064
-921	-92.1	-0.724	1.168	-0.454	-0.010	-155.7	78.81	74.92	-1.97	6.3	-1.210	1.231	-0.020
-920	-92	-0.752	1.168	-0.423	-0.007	-156.5	75.01	79.44	-2.05	6.4	-1.238	1.215	0.023
-919	-91.9	-0.783	1.168	-0.390	-0.005	-157.2	71.21	83.97	-2.02	6.5	-1.266	1.199	0.067
-918	-91.8	-0.811	1.168	-0.359	-0.002	-157.9	67.41	88.49	-2	6.6	-1.293	1.183	0.111
-917	-91.7	-0.842	1.168	-0.325	0.001	-158.6	63.61	93.01	-1.98	6.7	-1.321	1.166	0.154
-916	-91.6	-0.864	1.156	-0.291	0.001	-157.7	59.09	96.57	-2.04	6.8	-1.335	1.138	0.197
-915	-91.5	-0.884	1.137	-0.258	-0.005	-155.8	54.22	99.65	-1.93	6.9	-1.341	1.102	0.238
-914	-91.4	-0.900	1.120	-0.221	-0.001	-153.9	49.34	102.7	-1.86	7	-1.347	1.067	0.280

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 43 of 121
	IWPRD	01	0001	EL	ST	001	D1	

-913	-91.3	-0.920	1.100	-0.188	-0.008	-152	44.46	105.8	-1.74	7.1	-1.353	1.031	0.322
-912	-91.2	-0.940	1.081	-0.151	-0.010	-150.2	39.58	108.9	-1.72	7.2	-1.360	0.996	0.364
-911	-91.1	-0.959	1.061	-0.117	-0.015	-148.3	34.7	112	-1.6	7.3	-1.366	0.961	0.406
-910	-91	-0.976	1.044	-0.081	-0.013	-146.4	29.82	115.1	-1.48	7.4	-1.373	0.925	0.448
-909	-90.9	-0.996	1.024	-0.047	-0.019	-144.6	24.94	118.1	-1.56	7.5	-1.379	0.890	0.489
-908	-90.8	-1.016	1.005	-0.011	-0.022	-142.7	20.06	121.2	-1.44	7.6	-1.385	0.854	0.531
-907	-90.7	-1.033	0.987	0.022	-0.024	-140.8	15.18	124.3	-1.32	7.7	-1.391	0.819	0.573
-906	-90.6	-1.052	0.968	0.058	-0.026	-139	10.3	127.4	-1.3	7.8	-1.398	0.784	0.615
-905	-90.5	-1.072	0.948	0.092	-0.031	-137.1	5.431	130.4	-1.269	7.9	-1.404	0.748	0.656
-904	-90.4	-1.092	0.929	0.129	-0.034	-135.2	0.55	133.5	-1.15	8	-1.410	0.713	0.698
-903	-90.3	-1.109	0.912	0.162	-0.035	-133.3	-4.33	136.6	-1.03	8.1	-1.417	0.677	0.740
-902	-90.2	-1.128	0.892	0.199	-0.037	-131.5	-9.21	139.7	-1.011	8.2	-1.423	0.642	0.782
-901	-90.1	-1.148	0.872	0.232	-0.044	-129.6	-14.1	142.8	-0.89	8.3	-1.430	0.606	0.823
-900	-90	-1.165	0.856	0.266	-0.043	-127.7	-19	145.8	-0.86	8.4	-1.436	0.571	0.865
-899	-89.9	-1.168	0.822	0.300	-0.046	-122.2	-22	143.3	-0.86	8.5	-1.394	0.526	0.867
-898	-89.8	-1.168	0.788	0.334	-0.046	-116.7	-24.9	140.7	-0.94	8.6	-1.351	0.482	0.869
-897	-89.7	-1.168	0.757	0.364	-0.047	-111.2	-27.9	138.1	-1.03	8.7	-1.308	0.437	0.871
-896	-89.6	-1.168	0.724	0.398	-0.046	-105.7	-30.9	135.6	-1.02	8.8	-1.266	0.392	0.874
-895	-89.5	-1.168	0.693	0.429	-0.046	-100.2	-33.9	133	-1.11	8.9	-1.224	0.348	0.876
-894	-89.4	-1.168	0.659	0.463	-0.046	-94.74	-36.9	130.4	-1.24	9	-1.182	0.304	0.878
-893	-89.3	-1.168	0.628	0.494	-0.046	-89.24	-39.9	127.9	-1.22	9.1	-1.140	0.259	0.881
-892	-89.2	-1.168	0.595	0.527	-0.046	-83.75	-42.9	125.3	-1.32	9.2	-1.097	0.215	0.883
-891	-89.1	-1.168	0.564	0.558	-0.046	-78.24	-45.9	122.7	-1.41	9.3	-1.055	0.170	0.885
-890	-89	-1.168	0.530	0.592	-0.046	-72.75	-48.9	120.1	-1.5	9.4	-1.012	0.125	0.887
-889	-88.9	-1.168	0.499	0.623	-0.046	-67.25	-51.8	117.6	-1.49	9.5	-0.970	0.081	0.889
-888	-88.8	-1.168	0.465	0.656	-0.047	-61.75	-54.8	115	-1.57	9.6	-0.928	0.036	0.891
-887	-88.7	-1.168	0.435	0.687	-0.046	-56.25	-57.8	112.4	-1.67	9.7	-0.885	-0.008	0.893
-886	-88.6	-1.168	0.401	0.721	-0.046	-50.75	-60.8	109.9	-1.65	9.8	-0.843	-0.053	0.896
-885	-88.5	-1.168	0.370	0.752	-0.046	-45.25	-63.8	107.3	-1.74	9.9	-0.801	-0.097	0.898
-884	-88.4	-1.168	0.336	0.758	-0.074	-39.76	-66.8	104.7	-1.84	10	-0.758	-0.142	0.900
-883	-88.3	-1.142	0.303	0.797	-0.042	-34.14	-69.5	101.8	-1.83	10.1	-0.714	-0.186	0.899
-882	-88.2	-1.061	0.261	0.755	-0.045	-28.3	-71.6	98.07	-1.84	10.2	-0.663	-0.227	0.891
-881	-88.1	-0.979	0.221	0.715	-0.043	-22.45	-73.8	94.37	-1.83	10.3	-0.613	-0.269	0.882
-880	-88	-0.900	0.182	0.676	-0.042	-16.61	-75.9	90.67	-1.82	10.4	-0.563	-0.311	0.874







	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Table All.2 continuation in rows instantaneous values of the measured data, CT model used to omit the errors

Vn0(p.u.))	Pr	Qr	Sr	Ps	Qs	Ss	Pt	Qt	St	P-P0	Q	S	S0	P+S0*
0	148.59	108.87	184.21	-5.74	51.56	51.88	121.70	-52.67	132.61	264.55	107.77	285.66	0.00	264.55
0	146.41	109.46	182.80	-6.02	49.57	49.93	122.65	-51.63	133.08	263.04	107.39	284.12	0.00	263.04
0	139.72	111.29	178.62	-6.55	42.99	43.49	125.80	-48.51	134.83	258.97	105.77	279.74	0.00	258.97
0	132.92	112.77	174.31	-6.66	36.24	36.85	129.41	-45.37	137.13	255.66	103.64	275.87	0.00	255.66
0	126.22	114.08	170.14	-6.48	29.98	30.68	133.13	-42.04	139.61	252.87	102.03	272.68	0.00	252.87
0	119.63	115.27	166.13	-5.87	23.53	24.26	136.68	-38.47	141.99	250.43	100.34	269.78	0.00	250.43
0	113.52	116.57	162.72	-5.01	17.70	18.39	139.89	-34.63	144.11	248.40	99.644	267.64	0.00	248.40
0	107.34	117.63	159.25	-3.63	11.40	11.96	143.64	-30.71	146.88	247.35	98.324	266.18	0.00	247.35
0	101.21	118.45	155.81	-2.07	5.85	6.21	147.27	-26.56	149.64	246.41	97.749	265.09	0.00	246.41
0	95.61	119.42	152.98	-0.12	0.30	0.32	150.60	-22.18	152.23	246.09	97.538	264.72	0.00	246.09
0	89.79	119.99	149.87	2.25	-5.25	5.72	154.44	-17.67	155.45	246.48	97.064	264.90	0.00	246.48
0	84.22	120.57	147.07	4.85	-10.37	11.45	158.30	-12.96	158.83	247.37	97.242	265.80	0.00	247.37
0	78.72	120.89	144.26	8.08	-15.92	17.85	162.20	-8.05	162.40	248.99	96.927	267.19	0.00	248.99
0	73.63	121.40	141.99	11.37	-20.74	23.66	165.42	-2.92	165.45	250.42	97.737	268.82	0.00	250.42
0	68.50	121.48	139.46	15.34	-26.00	30.19	169.43	2.36	169.45	253.27	97.842	271.51	0.00	253.27
0	63.55	121.57	137.18	19.34	-30.54	36.15	173.41	7.86	173.58	256.30	98.891	274.72	0.00	256.30
0	58.68	121.31	134.76	23.95	-35.34	42.69	177.19	13.55	177.70	259.82	99.514	278.22	0.00	259.82
0	54.18	121.45	132.99	28.75	-39.73	49.04	180.73	19.39	181.77	263.66	101.12	282.39	0.00	263.66
0	48.61	118.51	128.09	33.24	-43.12	54.45	181.05	24.99	182.77	262.90	100.38	281.41	0.00	262.90
1	42.79	114.10	121.86	37.17	-45.32	58.61	178.98	30.32	181.53	258.94	99.101	277.25	0.63	259.56
1	37.41	109.94	116.13	41.49	-47.53	63.09	176.90	35.64	180.45	255.80	98.05	273.95	0.74	256.54
1	32.16	105.28	110.08	45.88	-49.35	67.38	174.75	40.97	179.49	252.80	96.903	270.73	1.31	254.10
1	27.42	101.10	104.75	50.60	-51.09	71.91	172.74	46.29	178.84	250.76	96.299	268.62	1.42	252.18
1	22.87	96.34	99.02	55.26	-52.38	76.14	170.67	51.63	178.30	248.79	95.582	266.52	2.11	250.90
1	18.79	92.15	94.05	60.44	-53.77	80.89	168.59	56.95	177.95	247.82	95.33	265.53	1.99	249.81
1	14.89	87.29	88.55	65.45	-54.56	85.21	166.46	62.27	177.73	246.80	95.002	264.45	2.67	249.47
1	11.40	82.86	83.64	71.02	-55.45	90.10	164.36	67.60	177.72	246.78	95.008	264.44	2.67	249.45
1	8.17	77.91	78.33	76.78	-56.09	95.08	162.26	72.92	177.89	247.21	94.741	264.74	3.02	250.23
1	5.32	73.38	73.57	82.35	-56.22	99.71	160.16	78.26	178.26	247.83	95.414	265.56	3.36	251.19
1	2.77	68.49	68.54	88.49	-56.38	104.92	158.06	83.58	178.80	249.32	95.682	267.05	3.59	252.91
1	0.56	63.87	63.87	94.42	-56.05	109.80	155.97	88.91	179.53	250.94	96.723	268.93	3.93	254.87
1	-1.34	58.76	58.78	100.98	-55.73	115.34	153.93	94.23	180.48	253.57	97.26	271.59	4.27	257.84
1	-2.91	54.05	54.12	107.27	-54.95	120.53	151.83	99.56	181.57	256.19	98.662	274.53	4.61	260.80
1	-4.15	48.96	49.14	114.18	-54.15	126.37	149.73	104.89	182.81	259.76	99.696	278.24	4.84	264.60
1	-5.09	44.16	44.45	120.83	-52.92	131.91	147.64	110.20	184.23	263.38	101.43	282.23	5.18	268.56

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 45 of 121
	IWPRD	01	0001	EL	ST	001	D1	

1	-5.47	37.22	37.62	124.73	-50.12	134.42	141.25	112.40	180.52	260.52	99.502	278.87	5.63	266.15
1	-5.57	31.08	31.58	128.88	-47.16	137.23	134.69	114.22	176.60	258.00	98.142	276.04	5.18	263.18
1	-5.22	24.60	25.15	132.83	-43.89	139.90	128.18	115.89	172.80	255.80	96.593	273.43	5.18	260.98
1	-4.57	18.59	19.15	136.57	-40.32	142.40	121.89	117.45	169.27	253.89	95.717	271.34	5.18	259.07
1	-3.48	12.41	12.89	140.60	-36.63	145.29	116.00	119.24	166.36	253.12	95.023	270.37	5.52	258.64
1	-2.11	6.68	7.00	144.81	-32.74	148.46	109.91	120.59	163.16	252.60	94.533	269.71	5.18	257.78
1	-0.28	0.80	0.85	148.64	-28.53	151.35	104.01	121.84	160.20	252.37	94.108	269.35	5.41	257.78
1	1.70	-4.35	4.67	152.76	-24.16	154.66	98.20	122.97	157.37	252.65	94.465	269.73	4.95	257.60
1	4.13	-9.65	10.50	157.13	-19.58	158.34	92.86	124.38	155.22	254.12	95.142	271.35	4.95	259.07
1	7.07	-15.09	16.67	161.06	-14.73	161.73	87.31	125.40	152.80	255.43	95.58	272.73	5.18	260.61
1	10.23	-20.10	22.55	165.27	-9.69	165.56	81.89	126.22	150.46	257.40	96.431	274.87	4.95	262.35
1	13.90	-25.26	28.83	169.58	-4.43	169.64	76.76	127.06	148.45	260.25	97.379	277.87	5.07	265.31
1	17.70	-29.84	34.69	173.54	1.07	173.54	71.78	127.94	146.70	263.02	99.177	281.10	5.18	268.20
1	22.20	-34.84	41.31	178.08	6.78	178.21	66.90	128.58	144.95	267.17	100.52	285.46	5.29	272.47
1	26.71	-39.13	47.38	182.42	12.72	182.86	62.02	128.98	143.11	271.16	102.57	289.91	4.95	276.11
1	31.96	-43.81	54.22	186.47	18.85	187.42	57.29	129.26	141.39	275.72	104.31	294.79	5.29	281.01
1	36.67	-47.19	59.77	189.09	24.96	190.73	52.28	128.27	138.52	278.04	106.04	297.57	4.84	282.87
1	41.04	-49.62	64.39	187.00	30.42	189.46	46.20	123.93	132.26	274.24	104.73	293.56	4.61	278.85
1	45.25	-51.44	68.51	184.84	35.88	188.29	40.56	119.76	126.44	270.66	104.2	290.02	4.27	274.92
1	49.97	-53.39	73.13	182.68	41.35	187.30	35.09	115.08	120.31	267.74	103.04	286.89	3.93	271.67
1	54.58	-54.76	77.31	180.59	46.82	186.56	30.08	110.89	114.90	265.25	102.96	284.53	3.59	268.83
1	59.68	-56.23	82.00	178.43	52.28	185.93	25.30	106.27	109.24	263.41	102.32	282.58	3.36	266.77
1	64.62	-57.15	86.26	176.27	57.75	185.49	20.92	101.91	104.03	261.80	102.51	281.16	3.02	264.82
1	70.12	-58.17	91.11	174.20	63.21	185.31	16.77	97.10	98.54	261.10	102.14	280.36	2.68	263.77
1	75.42	-58.63	95.53	172.04	68.67	185.24	13.02	92.64	93.55	260.48	102.69	279.99	2.33	262.81
1	81.28	-59.15	100.52	169.87	74.15	185.35	9.51	87.67	88.18	260.67	102.67	280.16	1.99	262.66
1	87.37	-59.43	105.67	167.78	79.63	185.72	6.36	82.86	83.10	261.52	103.05	281.09	1.77	263.28
1	93.21	-59.20	110.42	165.62	85.09	186.20	3.56	78.26	78.34	262.38	104.15	282.30	1.42	263.81
1	99.64	-59.01	115.80	163.46	90.55	186.86	1.05	73.14	73.15	264.15	104.68	284.13	1.08	265.23
1	105.88	-58.34	120.89	161.37	96.02	187.77	-1.12	68.50	68.51	266.13	106.18	286.53	0.74	266.87
1	112.69	-57.67	126.59	159.21	101.49	188.80	-2.97	63.44	63.51	268.93	107.26	289.53	0.51	269.44
1	119.25	-56.54	131.97	157.05	106.96	190.01	-4.52	58.65	58.83	271.78	109.07	292.85	0.17	271.95
1	126.43	-55.40	138.04	154.89	112.42	191.39	-5.70	53.34	53.64	275.62	110.36	296.89	-0.17	275.45
1	131.11	-52.80	141.34	149.56	115.52	188.98	-6.51	47.48	47.93	274.16	110.2	295.48	-0.17	273.99
1	134.77	-49.57	143.60	142.51	117.25	184.54	-7.00	41.59	42.18	270.28	109.27	291.53	0.51	270.79
1	137.83	-45.93	145.28	135.85	119.03	180.62	-7.04	35.19	35.89	266.63	108.3	287.79	0.06	266.69
1	141.55	-42.31	147.74	128.97	120.44	176.46	-6.89	29.57	30.36	263.64	107.7	284.79	0.85	264.49
1	145.36	-38.48	150.37	122.43	121.83	172.72	-6.25	23.47	24.29	261.54	106.82	282.51	1.08	262.63

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No PHASE AREA TRAIN/UNIT DIS DOC SEQ REV IWPRD 01 0001 EL ST 001 D1					

1	148.99	-34.42	152.91	115.88	122.98	168.97	-5.40	17.96	18.75	259.46	106.51	280.47	1.65	261.11
1	152.33	-30.10	155.27	109.80	124.36	165.89	-4.13	12.27	12.95	258.00	106.53	279.13	1.42	259.42
1	156.16	-25.69	158.26	103.61	125.16	162.48	-2.62	7.04	7.51	257.16	106.5	278.34	2.11	259.27
1	160.03	-21.08	161.41	97.62	126.06	159.44	-0.67	1.63	1.76	256.99	106.61	278.22	2.45	259.44
1	163.45	-16.22	164.25	91.88	126.97	156.73	1.43	-3.20	3.51	256.76	107.55	278.38	2.68	259.44
1	167.27	-11.21	167.65	86.26	127.63	154.04	4.05	-8.34	9.27	257.58	108.09	279.34	2.90	260.48
1	171.16	-6.02	171.26	80.64	127.94	151.24	6.86	-13.05	14.74	258.67	108.87	280.64	3.58	262.25
1	175.14	-0.62	175.14	75.27	128.36	148.80	10.24	-18.04	20.74	260.64	109.7	282.78	3.81	264.46
1	178.66	4.97	178.73	70.20	128.94	146.81	13.63	-22.34	26.17	262.49	111.57	285.21	3.93	266.42
1	182.60	10.75	182.91	65.11	128.97	144.47	17.69	-27.07	32.34	265.39	112.65	288.31	4.15	269.54
1	186.66	16.73	187.41	60.12	128.88	142.21	21.73	-31.10	37.94	268.50	114.51	291.90	4.95	273.46
1	190.19	22.85	191.56	55.56	129.17	140.62	26.16	-35.14	43.81	271.91	116.88	295.96	4.84	276.75
1	185.10	26.53	186.99	49.18	121.92	131.46	29.60	-37.93	48.11	263.88	110.53	286.09	5.18	269.06
1	179.45	30.13	181.97	43.16	114.76	122.61	33.03	-40.33	52.12	255.64	104.57	276.20	5.18	260.82
1	173.81	33.75	177.05	37.63	108.21	114.56	36.08	-41.88	55.27	247.51	100.08	266.98	5.29	252.81
1	168.23	37.36	172.33	32.32	101.62	106.64	39.57	-43.52	58.82	240.12	95.457	258.39	5.18	245.30
1	162.59	40.97	167.67	27.42	95.41	99.27	42.75	-44.47	61.69	232.76	91.907	250.24	5.18	237.93
1	156.97	44.59	163.18	22.75	88.96	91.82	46.24	-45.38	64.79	225.96	88.158	242.55	5.18	231.14
1	151.39	48.19	158.87	18.51	83.15	85.18	49.48	-45.61	67.30	219.38	85.724	235.53	5.18	224.55
1	145.75	51.80	154.68	14.52	77.18	78.53	52.91	-45.66	69.89	213.18	83.315	228.88	5.18	218.36
1	140.10	55.42	150.66	10.90	71.64	72.47	56.15	-45.17	72.07	207.15	81.899	222.75	5.18	212.33
1	134.46	59.03	146.84	7.56	65.90	66.33	59.71	-44.56	74.51	201.73	80.367	217.15	5.18	206.91
1	128.88	62.64	143.30	4.59	60.76	60.93	63.02	-43.35	76.49	196.49	80.049	212.17	5.18	201.67
1	123.23	66.24	139.91	1.92	55.37	55.40	66.51	-41.91	78.61	191.67	79.697	207.57	5.29	196.96
1	117.59	69.87	136.78	-0.41	50.63	50.63	69.82	-39.98	80.45	186.99	80.511	203.59	5.18	192.17
1	112.01	73.47	133.95	-2.41	45.64	45.70	73.48	-37.86	82.66	183.08	81.245	200.30	5.18	188.26
1	106.36	77.08	131.36	-4.10	41.12	41.32	76.81	-35.21	84.50	179.08	82.988	197.37	5.18	184.26
1	100.72	80.69	129.06	-5.42	36.44	36.84	77.60	-31.18	83.63	172.90	85.946	193.09	8.37	181.27
1	92.67	82.10	123.81	-6.40	31.95	32.59	81.50	-28.15	86.23	167.78	85.897	188.49	4.73	172.50
1	80.04	78.60	112.18	-6.75	26.52	27.37	76.48	-22.11	79.62	149.77	83.015	171.24	5.07	154.84
1	68.27	74.70	101.20	-6.78	21.61	22.65	71.77	-16.61	73.66	133.26	79.701	155.28	4.84	138.10
1	57.64	70.65	91.18	-6.45	17.11	18.28	67.22	-11.62	68.22	118.41	76.141	140.78	4.72	123.13







	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 47 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Table All.2 continuation in rows instantaneous values of the measured data, CT model used to omit the errors

Irf(A)	Isf(A)	Itf(A)	Irf+Isf+Itf (A)	Pf	Qf	Sf	St=S+S0+Sf	3I0(A)
31.57	-12.48	-19.08	0.01	0.55	0.31	0.63	286.28	19
31.45	-12.16	-19.29	0	0.54	0.31	0.62	284.74	19
31.09	-11.19	-19.9	0	0.53	0.30	0.61	280.35	56
30.72	-10.22	-20.51	-0.01	0.53	0.30	0.61	276.48	56
30.36	-9.25	-21.12	-0.013	0.52	0.30	0.60	273.28	19
29.99	-8.28	-21.73	-0.022	0.52	0.29	0.59	270.38	19
29.63	-7.31	-22.35	-0.031	0.51	0.29	0.59	268.23	44
29.27	-6.34	-22.96	-0.033	0.51	0.29	0.59	266.77	56
28.90	-5.37	-23.57	-0.042	0.51	0.29	0.58	265.67	19
28.54	-4.40	-24.18	-0.041	0.51	0.29	0.58	265.30	56
28.18	-3.43	-24.79	-0.042	0.51	0.29	0.58	265.49	31
27.81	-2.46	-25.4	-0.051	0.51	0.29	0.59	266.38	-6
27.45	-1.49	-26.01	-0.053	0.51	0.29	0.59	267.78	-6
27.08	-0.52	-26.63	-0.072	0.51	0.29	0.59	269.41	31
26.72	0.45	-27.24	-0.074	0.52	0.30	0.60	272.11	31
26.36	1.42	-27.85	-0.073	0.52	0.30	0.61	275.32	-6
25.99	2.39	-28.46	-0.082	0.53	0.30	0.61	278.84	-6
25.63	3.36	-29.07	-0.083	0.54	0.31	0.62	283.01	31
24.99	4.29	-29.37	-0.092	0.54	0.31	0.62	282.03	-6
24.22	5.20	-29.51	-0.087	0.53	0.30	0.61	278.49	-69
23.45	6.12	-29.65	-0.085	0.52	0.30	0.60	275.29	-81
22.67	7.03	-29.79	-0.09	0.52	0.30	0.60	272.64	-144
21.90	7.94	-29.93	-0.087	0.51	0.29	0.59	270.63	-156
21.12	8.86	-30.07	-0.092	0.51	0.29	0.59	269.21	-231
20.35	9.77	-30.21	-0.09	0.51	0.29	0.58	268.10	-219
19.58	10.68	-30.35	-0.09	0.51	0.29	0.58	267.71	-294
18.81	11.60	-30.49	-0.08	0.50	0.29	0.58	267.69	-294
18.03	12.50	-30.63	-0.1	0.51	0.29	0.58	268.34	-331
17.26	13.42	-30.77	-0.09	0.51	0.29	0.59	269.50	-369
16.49	14.34	-30.91	-0.08	0.51	0.29	0.59	271.23	-394
15.71	15.25	-31.05	-0.09	0.51	0.30	0.59	273.46	-431
14.94	16.16	-31.19	-0.09	0.52	0.30	0.60	276.45	-469
14.17	17.08	-31.33	-0.08	0.53	0.30	0.61	279.75	-506
13.39	17.99	-31.47	-0.09	0.53	0.31	0.61	283.69	-531
12.62	18.90	-31.61	-0.09	0.54	0.31	0.62	288.04	-569

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 48 of 121
	IWPRD	01	0001	EL	ST	001	D1	

11.64	19.51	-31.25	-0.1	0.53	0.31	0.61	285.12	-619
10.67	20.12	-30.87	-0.08	0.52	0.30	0.61	281.82	-569
9.69	20.72	-30.51	-0.096	0.52	0.30	0.60	279.21	-569
8.72	21.33	-30.14	-0.093	0.51	0.30	0.59	277.11	-569
7.74	21.93	-29.77	-0.097	0.51	0.30	0.59	276.47	-606
6.77	22.54	-29.4	-0.093	0.50	0.29	0.58	275.48	-569
5.79	23.15	-29.03	-0.087	0.50	0.29	0.58	275.34	-594
4.82	23.75	-28.66	-0.094	0.50	0.29	0.58	275.26	-544
2.87	24.96	-27.92	-0.094	0.51	0.28	0.58	276.88	-544
1.89	25.57	-27.55	-0.088	0.51	0.28	0.58	278.49	-569
0.91	26.18	-27.18	-0.086	0.51	0.28	0.59	280.40	-544
-0.06	26.78	-26.82	-0.098	0.52	0.28	0.59	283.52	-556
-1.04	27.39	-26.45	-0.096	0.52	0.29	0.60	286.87	-569
-2.01	28.00	-26.08	-0.089	0.53	0.29	0.60	291.35	-581
-2.99	28.60	-25.71	-0.096	0.54	0.29	0.61	295.47	-544
-3.94	29.05	-25.2	-0.093	0.54	0.30	0.62	300.70	-581
-4.86	29.19	-24.43	-0.101	0.54	0.30	0.61	303.02	-531
-5.78	29.33	-23.65	-0.099	0.53	0.29	0.61	298.77	-506
-6.70	29.47	-22.88	-0.109	0.53	0.29	0.60	294.89	-469
-7.62	29.61	-22.1	-0.107	0.52	0.28	0.59	291.41	-431
-8.54	29.76	-21.32	-0.095	0.52	0.28	0.59	288.70	-394
-9.46	29.90	-20.55	-0.105	0.51	0.28	0.59	286.53	-369
-10.37	30.04	-19.77	-0.1	0.51	0.28	0.58	284.75	-331
-11.29	30.17	-19	-0.12	0.51	0.28	0.58	283.62	-294
-12.21	30.31	-18.22	-0.12	0.51	0.28	0.58	282.90	-256
-13.13	30.45	-17.45	-0.13	0.51	0.28	0.58	282.73	-219
-14.05	30.59	-16.67	-0.13	0.52	0.28	0.59	283.44	-194
-14.97	30.73	-15.89	-0.13	0.52	0.28	0.59	284.31	-156
-15.89	30.87	-15.12	-0.14	0.52	0.28	0.59	285.81	-119
-16.81	31.02	-14.34	-0.13	0.53	0.28	0.60	287.87	-81
-17.72	31.16	-13.56	-0.12	0.54	0.29	0.61	290.65	-57
-18.64	31.30	-12.79	-0.13	0.54	0.29	0.62	293.63	-19
-19.36	31.11	-11.88	-0.13	0.55	0.29	0.62	297.34	19
-19.97	30.74	-10.9	-0.13	0.54	0.29	0.61	295.92	19
-20.59	30.38	-9.921	-0.131	0.53	0.29	0.61	292.65	-56
-21.20	30.02	-8.945	-0.125	0.53	0.28	0.60	288.44	-6
-21.82	29.66	-7.965	-0.125	0.52	0.28	0.59	286.24	-94
-22.43	29.30	-6.988	-0.118	0.52	0.28	0.59	284.19	-119

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 49 of 121
	IWPRD	01	0001	EL	ST	001	D1	

-23.04	28.94	-6.009	-0.109	0.52	0.28	0.59	282.71	-181
-23.66	28.58	-5.032	-0.112	0.52	0.27	0.58	281.14	-156
-24.27	28.22	-4.053	-0.103	0.51	0.27	0.58	281.03	-231
-24.89	27.86	-3.076	-0.106	0.52	0.27	0.58	281.25	-269
-25.50	27.49	-2.097	-0.107	0.52	0.27	0.58	281.64	-294
-26.12	27.13	-1.12	-0.11	0.52	0.28	0.59	282.83	-319
-26.73	26.77	-0.14	-0.1	0.52	0.28	0.59	284.82	-394
-27.34	26.41	0.836	-0.094	0.53	0.28	0.60	287.20	-419
-27.96	26.05	1.816	-0.094	0.53	0.28	0.60	289.75	-432
-28.57	25.69	2.793	-0.087	0.54	0.29	0.61	293.07	-456
-29.19	25.33	3.769	-0.091	0.55	0.29	0.62	297.47	-544
-29.30	24.58	4.634	-0.086	0.55	0.29	0.62	301.42	-531
-29.42	23.84	5.495	-0.085	0.53	0.28	0.60	291.87	-569
-29.53	23.09	6.357	-0.083	0.51	0.27	0.58	281.96	-569
-29.65	22.34	7.218	-0.092	0.50	0.26	0.56	272.84	-581
-29.77	21.60	8.08	-0.09	0.48	0.25	0.54	264.12	-569
-29.88	20.85	8.945	-0.085	0.47	0.24	0.53	255.95	-569
-30.00	20.10	9.806	-0.094	0.46	0.23	0.51	248.24	-569
-30.11	19.36	10.67	-0.08	0.44	0.23	0.50	241.21	-569
-30.23	18.61	11.53	-0.09	0.43	0.22	0.48	234.55	-569
-30.34	17.86	12.39	-0.09	0.42	0.22	0.47	228.40	-569
-30.46	17.12	13.26	-0.08	0.41	0.21	0.46	222.79	-569
-30.58	16.37	14.12	-0.09	0.40	0.21	0.45	217.80	-569
-30.69	15.63	14.98	-0.08	0.39	0.21	0.44	213.31	-581
-30.81	14.88	15.84	-0.09	0.38	0.21	0.43	209.20	-569
-30.93	14.13	16.7	-0.1	0.37	0.21	0.42	205.90	-569
-31.04	13.39	17.57	-0.08	0.36	0.22	0.42	202.97	-569
-30.98	12.58	18.3	-0.1	0.35	0.22	0.41	201.86	-919
-30.55	11.68	18.79	-0.08	0.33	0.22	0.40	193.61	-519
-30.13	10.76	19.27	-0.1	0.32	0.22	0.38	176.69	-557
-29.70	9.85	19.76	-0.095	0.30	0.22	0.37	160.49	-532
-29.28	8.94	20.24	-0.098	0.29	0.22	0.36	145.86	-519



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Table All.3. Instantaneous values of the recorded currents data. Assumed A/D records error omitted from the summation of the currents.

Table All.3 Instantaneous values of the recorded currents data. Assumed A/D records error omitted from the summation of the currents:

CURSOR	TIME	Ir	Is	It	3I0=Ir+Is+It	Assumed A/D Error	3I0-A/D Error			
-984	-98.4	1.123	-0.314	-0.808	0.001	0	0.001			
-983	-98.3	1.117	-0.303	-0.813	0.001	0	0.001			
-982	-98.2	1.1	-0.266	-0.83	0.004	0	0.004			
-981	-98.1	1.081	-0.227	-0.85	0.004	0	0.004			
-980	-98	1.061	-0.19	-0.87	0.001	0	0.001			
-979	-97.9	1.041	-0.151	-0.889	0.001	0	0.001			
-978	-97.8	1.024	-0.115	-0.906	0.003	0	0.003			
-977	-97.7	1.005	-0.075	-0.926	0.004	0	0.004			
-976	-97.6	0.985	-0.039	-0.945	0.001	0	0.001			
-975	-97.5	0.968	-0.002	-0.962	0.004	0	0.004			
-974	-97.4	0.948	0.036	-0.982	0.002	0	0.002			
-973	-97.3	0.929	0.072	-1.002	-0.001	0	-0.001			
-972	-97.2	0.909	0.112	-1.022	-0.001	0	-0.001			
-971	-97.1	0.892	0.148	-1.038	0.002	0	0.002			
-970	-97	0.872	0.188	-1.058	0.002	0	0.002			
-969	-96.9	0.853	0.224	-1.078	-0.001	0	-0.001			
-968	-96.8	0.833	0.263	-1.097	-0.001	0	-0.001			
-967	-96.7	0.816	0.3	-1.114	0.002	0	0.002			
-966	-96.6	0.788	0.334	-1.123	-0.001	0	-0.001			
-965	-96.5	0.755	0.362	-1.123	-0.006	0	-0.006			
-964	-96.4	0.724	0.392	-1.123	-0.007	-0.00274125	-0.00425875			
-963	-96.3	0.69	0.421	-1.123	-0.012	-0.007881094	-0.004118906			
-962	-96.2	0.659	0.451	-1.123	-0.013	-0.014627139	0.001627139			
-961	-96.1	0.625	0.479	-1.123	-0.019	-0.021935354	0.002935354			
-960	-96	0.595	0.51	-1.123	-0.018	-0.028786806	0.010786806			
-959	-95.9	0.561	0.538	-1.123	-0.024	-0.034439254	0.010439254			
-958	-95.8	0.53	0.569	-1.123	-0.024	-0.03856083	0.01456083			
-957	-95.7	0.496	0.6	-1.123	-0.027	-0.041210415	0.014210415			
-956	-95.6	0.465	0.628	-1.123	-0.03	-0.042700807	0.012700807			
-955	-95.5	0.432	0.659	-1.123	-0.032	-0.043425302	0.011425302			
-954	-95.4	0.401	0.687	-1.123	-0.035	-0.043724157	0.008724157			





**X III HYDRO POWER GENERATION PLANT
UNIT 7 GENERATOR DAMAGE**





XXXXXXXX

Document Title	DOCUMENT No							Page 51 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

-953	-95.3	0.367	0.718	-1.123	-0.038	-0.043826039	0.005826039			
-952	-95.2	0.336	0.746	-1.123	-0.041	-0.043853632	0.002853632			
-951	-95.1	0.303	0.777	-1.123	-0.043	-0.043859204	0.000859204			
-950	-95	0.272	0.805	-1.123	-0.046	-0.04385995	-0.00214005			
-949	-94.9	0.232	0.827	-1.109	-0.05	-0.04386	-0.00614			
-948	-94.8	0.196	0.85	-1.092	-0.046	-0.04386	-0.00214			
-947	-94.7	0.157	0.872	-1.075	-0.046	-0.04386	-0.00214			
-946	-94.6	0.12	0.892	-1.058	-0.046	-0.04386	-0.00214			
-945	-94.5	0.081	0.914	-1.044	-0.049	-0.04386	-0.00514			
-944	-94.4	0.044	0.937	-1.027	-0.046	-0.04386	-0.00214			
-943	-94.3	0.005	0.957	-1.01	-0.048	-0.04386	-0.00414			
-942	-94.2	-0.03	0.979	-0.993	-0.044	-0.04386	-0.00014			
-941	-94.1	-0.067	1.002	-0.979	-0.044	-0.04386	-0.00014			
-940	-94	-0.106	1.022	-0.962	-0.046	-0.04386	-0.00214			
-939	-93.9	-0.143	1.044	-0.945	-0.044	-0.04386	-0.00014			
-938	-93.8	-0.182	1.066	-0.929	-0.045	-0.04386	-0.00114			
-937	-93.7	-0.218	1.086	-0.914	-0.046	-0.04386	-0.00214			
-936	-93.6	-0.258	1.109	-0.898	-0.047	-0.04386	-0.00314			
-935	-93.5	-0.294	1.131	-0.881	-0.044	-0.04386	-0.00014			
-934	-93.4	-0.334	1.151	-0.864	-0.047	-0.04386	-0.00314			
-933	-93.3	-0.367	1.168	-0.844	-0.043	-0.04386	0.00086			
-932	-93.2	-0.398	1.168	-0.811	-0.041	-0.04111875	0.00011875			
-931	-93.1	-0.426	1.168	-0.78	-0.038	-0.035978906	-0.002021094			
-930	-93	-0.457	1.168	-0.746	-0.035	-0.029232861	-0.005767139			
-929	-92.9	-0.485	1.168	-0.715	-0.032	-0.021924646	-0.010075354			
-928	-92.8	-0.516	1.168	-0.682	-0.03	-0.015073194	-0.014926806			
-927	-92.7	-0.544	1.168	-0.651	-0.027	-0.009420746	-0.017579254			
-926	-92.6	-0.575	1.168	-0.617	-0.024	-0.00529917	-0.01870083			
-925	-92.5	-0.603	1.168	-0.586	-0.021	-0.002649585	-0.018350415			
-924	-92.4	-0.634	1.168	-0.552	-0.018	-0.001159193	-0.016840807			
-923	-92.3	-0.665	1.168	-0.519	-0.016	-0.000434698	-0.015565302			
-922	-92.2	-0.693	1.168	-0.488	-0.013	-0.000135843	-0.012864157			
-921	-92.1	-0.724	1.168	-0.454	-0.01	-3.39607E-05	-0.009966039			
-920	-92	-0.752	1.168	-0.423	-0.007	-6.36764E-06	-0.006993632			
-919	-91.9	-0.783	1.168	-0.39	-0.005	-7.95955E-07	-0.004999204			
-918	-91.8	-0.811	1.168	-0.359	-0.002	-4.97472E-08	-0.00199995			
-917	-91.7	-0.842	1.168	-0.325	0.001	-1.78671E-22	0.001			

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 52 of 121
	IWPRD	01	0001	EL	ST	001	D1	

-916	-91.6	-0.864	1.156	-0.291	0.001	-0.00274125	0.00374125			
-915	-91.5	-0.884	1.137	-0.258	-0.005	-0.007881094	0.002881094			
-914	-91.4	-0.9	1.12	-0.221	-0.001	-0.014627139	0.013627139			
-913	-91.3	-0.92	1.1	-0.188	-0.008	-0.021935354	0.013935354			
-912	-91.2	-0.94	1.081	-0.151	-0.01	-0.028786806	0.018786806			
-911	-91.1	-0.959	1.061	-0.117	-0.015	-0.034439254	0.019439254			
-910	-91	-0.976	1.044	-0.081	-0.013	-0.03856083	0.02556083			
-909	-90.9	-0.996	1.024	-0.047	-0.019	-0.041210415	0.022210415			
-908	-90.8	-1.016	1.005	-0.011	-0.022	-0.042700807	0.020700807			
-907	-90.7	-1.033	0.987	0.022	-0.024	-0.043425302	0.019425302			
-906	-90.6	-1.052	0.968	0.058	-0.026	-0.043724157	0.017724157			
-905	-90.5	-1.072	0.948	0.092	-0.032	-0.043826039	0.011826039			
-904	-90.4	-1.092	0.929	0.129	-0.034	-0.043853632	0.009853632			
-903	-90.3	-1.109	0.912	0.162	-0.035	-0.043859204	0.008859204			
-902	-90.2	-1.128	0.892	0.199	-0.037	-0.04385995	0.00685995			
-901	-90.1	-1.148	0.872	0.232	-0.044	-0.04386	-0.00014			
-900	-90	-1.165	0.856	0.266	-0.043	-0.04386	0.00086			
-899	-89.9	-1.168	0.822	0.3	-0.046	-0.04386	-0.00214			
-898	-89.8	-1.168	0.788	0.334	-0.046	-0.04386	-0.00214			
-897	-89.7	-1.168	0.757	0.364	-0.047	-0.04386	-0.00314			
-896	-89.6	-1.168	0.724	0.398	-0.046	-0.04386	-0.00214			
-895	-89.5	-1.168	0.693	0.429	-0.046	-0.04386	-0.00214			
-894	-89.4	-1.168	0.659	0.463	-0.046	-0.04386	-0.00214			
-893	-89.3	-1.168	0.628	0.494	-0.046	-0.04386	-0.00214			
-892	-89.2	-1.168	0.595	0.527	-0.046	-0.04386	-0.00214			
-891	-89.1	-1.168	0.564	0.558	-0.046	-0.04386	-0.00214			
-890	-89	-1.168	0.53	0.592	-0.046	-0.04386	-0.00214			
-889	-88.9	-1.168	0.499	0.623	-0.046	-0.04386	-0.00214			
-888	-88.8	-1.168	0.465	0.656	-0.047	-0.04386	-0.00314			
-887	-88.7	-1.168	0.435	0.687	-0.046	-0.04386	-0.00214			
-886	-88.6	-1.168	0.401	0.721	-0.046	-0.04386	-0.00214			
-885	-88.5	-1.168	0.37	0.752	-0.046	-0.04386	-0.00214			

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX III

SYSTEM FAULT AND LOAD FLOW STUDIES

III.1 INITIAL CONDITION AND LOAD FLOW STUDIES

The initial condition prior to the fault plays an important role during the studies. To find out the initial condition prior to the fault the following records are investigated:

- a) Records of the fault currents and voltages from REG216 (figure 2). From this record it can be recognized that the voltage and current angle differences prior to the fault are as the followings:

In point -98: The instantaneous values of the currents: $I_R=1.123I_n$, $I_S=-0.314I_n$, $I_T=-0.808I_n$ considering +/- 120 degree phase angles, the current waves would be: $I_R=1.168I_n\sin(\omega t+104.4)$ $I_S=1.168I_n\sin(\omega t+104.4-120)$ $I_T=1.168I_n\sin(\omega t+104.4+120)$. 1.168In is the maximum value of the current, can be obtained from the record for unfaulted phase i.e. phase S. The errors exists between the instantaneous values of the currents and the formula obtained, are either because of the CT errors, considered in appendix II, or unbalanced operation.



The phase angles between the current and the voltage waveforms are very trustable. Therefore, they are used to obtain the MVAR generation of unit number seven prior to the fault. The phase angle between the voltage and currents are obtained as the followings:

Peak of phase S current: $1.168I_n$
The instantaneous current of phase S in peak of $V_{st}=0.805I_n$
Phase difference= $\arcsin(0.805/1.168)-90=43.6-90 = -46.4$ Degree
Phase difference between V_s and $V_{st}=-30$ Degree
Phase difference between V_s and $I_s = -16.4$ Degree

Assuming that the active power output was 280MW, we obtain the MVAR output as 82.4 MVAR

- b) From measuring equipment, the voltage of the 400KV busbar was measured and written to be 420 KV for unit 8. However, this measuring must be corrected according to the test obtained recently from unit 8 measuring device by the following correction:

$405 \times 413 / 420 = 398.25 \text{KV} = 0.996 \text{ P.U.}$ in 400KV base. The incoming voltage would be 0.997 P.U.

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 54 of 121
	IWPRD	01	0001	EL	ST	001	D1	

The magnitude of voltage of unit 7 can be obtained from the records to be: $156.7/(1.41)=111.13$ divide this by recording relationship that is 1.1, we obtain $V_g=1.01$ P.U.

The magnitude of current is $I=\text{SQRT}(280*280+82.4*82.4)/(1.731*1.01*15.75) = 10.599\text{KA}$

This is in close agreement with the value can be obtained from the record i.e. $1.168*12500/1.4=10.428\text{KA}$

Putting all these together in a load flow calculation environment the load flow condition prior to the fault can be obtained. This is $P=280\text{MW}$ and $Q=82.15\text{MVAR}$ $V_g=1.01$ P.U. and $V_{net}=0.997$ P.U.

On the other hand, from the table All.2 created in appendix II, the power MW and MVARs can be read in each instant of time, prior to single and double phase faults.

These are:

$P=263\text{MW}$ and $Q=100.4$ MVAR prior to single phase fault

$P=277\text{MW}$ and $Q=116.7$ MVAR prior to double phase fault

Remembering from appendix I that Q values are just valid for balanced and without harmonic circuits. However, the approximation is valid for our purposes.

Double phase fault is the major fault needs to be studied in the next section therefore; the following load flow conditions are recognized:

$P=277\text{MW}$, $Q=116.7\text{MVAR}$, $V_g=1.01\text{P.U.}$, $V_{net}=0.979$ P.U.

Considering the above discussions, and that the Q values obtained in the fault condition are not reliable values, and that the objective of this section which is fault level studies are not too much tolerated by the adjustments of these variables under the above boundary values, the following load flow conditions are assumed:

$P=280\text{MW}$

$Q=82\text{MVA}$

$V_g=1.01\text{P.U.}$

$V_{net}=0.997\text{P.U.}$

The service station consumptions are also ignored. The results of load flow studies are shown in figures All.1 and All.2.




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX	
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No PHASE AREA TRAIN/UNIT DIS DOC SEQ REV						Page 55 of 121
		IWRD	01	0001	EL	ST	001	D1	

Figure AIII.1: Load flow study of the plant, P.U. voltage magnitudes and angles, MW-MVAR flows are shown

LOAD FLOW RESULTS - BUSBAR PU VOLTS / ANGLE & LINE MW(KW) / MVAR(KVAR) LOADING








	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 56 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure All.2: Load flow study of the plant, P.U. voltage magnitudes and angles, current flows in Amper are shown



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 57 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

III.2 FAULT STUDIES:

Figures and listings provided in this section show the fault studies results. Since the generator has an internal four parallel windings, and the intermediate fault is just occurred in one of these windings, four generators are used to equalize the model of unit number 7 in the following fault studies. In this way, the generator located in junction GEN7 is the one that we put the internal faults. The currents contributions from the network would be those passing through the line between junctions J73 and J72 and the actual currents passing to the neutral would be the sum of the neutral intermediate winding fault current and those coming from the other three windings, these are the current passing through 3GEN7 toward GEN7.

Refer to the figures and listings provided in this section the fault studies calculation results are reported in two categories. The first one lists the fault results and the second one shows these results on single line diagram.

The following drawings and lists are reported:

- (1) Figure AIII.3 shows line to line fault levels (reported as maximum currents) for all the busbars of the system.
- (2) Figure AIII.4 shows the result of LL fault occurring in the slots 326 and 327 between phase R and T. Please read phase Yellow as phase T and phase Blue as phase R and phase Red as phase S. There are no much difference between this result and the LLG faults occurring in the slots 326, 327, and 217 (single phase fault) when the ferroresonance situations described in appendix VII are not considered.
- (3) The above fault flow result listings are provided in table AIII.1. Please read phase Yellow as phase T and phase Blue as phase R and phase Red as phase S.
- (4) Figure AIII.5, shows the same result as the previous for LLG fault study by impedance of 0.012 P.U. Unfortunately, the PASHA program is not capable of considering the fault impedance between the two phases and to ground simultaneously and neither can put the ground portion of the fault in another location as it happened in the actual system, in the present time.
- (5) Table AIII.2, shows the previous fault analysis list, with the readings mentioned in item 3 above.
- (6) Table AIII.3, shows the result of line to line fault when R phase in slot 127 is connected to T phase in slot 126 (phase R to the neutral point). According to the section 5 this fault is not the initial two phase fault.
- (7) Figure AIII.6 shows the flowing of 3I0 for LG faults with introducing the ferroresonance effect, due to the lose earth connection in the secondary side. The fault is located in J72 for flows clarity.

In all result lists the P.U. bases are as the followings:

P.U. base is 15.75KV for line to line voltages and $(100*1000 / 15.75*1.73205=3666A)$ Amper for currents in 15.75KV sections and 400KV for voltages and $(100*1000 / 400*1.73205=1443.4A)$ Amper for 400KV sections.




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX											
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No PHASE IWRD					AREA 01		TRAIN/UNIT 0001		DIS EL		DOC ST		SEQ 001		REV D1	

Figure AIII.3: shows line to line fault levels (reported as maximum currents) for all the busbars of the system.

LINE TO LINE FAULT LEVEL (MVA) FOR EACH BUSBAR AT T= 0.0ms



COPYRIGHT (C) TOM InC 1988 TIME : 01:45:42 27/11/2007



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 60 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Table AIII.1 the fault flow result listings of figure III.4. Please read phase Yellow as phase T and phase Blue as phase R and phase Red as phase S.

UNBALANCED FAULT STUDY RESULTS

=====

SYSTEM TITLE : X 3GENERATOR
STUDY TITLE :
FAULT IMPEDANCE (R AND X) = 0.0000 0.0000 PU
TIME AFTER FAULT INCIDENCE = 0.00 MSEC

LINE TO LINE

-INTERNAL FAULT IN GENERATOR

WINDING PERCENT FROM TERMINAL

PHASE B: 88. PHASE C: 75.

	RED PHASE		YELLOW PHASE		BLUE PHASE	
	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)
NEUTRAL SIDE	1.6599	8.82	8.6769	8.22	10.3367	-171.68
TERMINAL SIDE	1.6599	8.82	26.8864	-171.25	25.2265	8.75



-B U S B A R A C V O L T A G E S

BUSBAR	RED PHASE		YELLOW PHASE		BLUE PHASE		PHASE TO PHASE			AREA
	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	MAG (PU)	MAG (PU)	
3GEN7	1.013	29.850	0.526	-149.270	0.487	-151.100	0.889	0.024	0.866	UN7
J72	1.013	29.843	0.526	-149.305	0.487	-151.079	0.889	0.025	0.866	UN7
J73	1.013	29.842	0.526	-149.124	0.487	-151.276	0.888	0.025	0.866	UN7
J74	1.013	29.841	0.526	-148.942	0.487	-151.474	0.888	0.026	0.866	UN7
JT7	1.013	29.840	0.526	-148.760	0.487	-151.671	0.888	0.027	0.866	UN7
PT3	0.888	30.195	0.025	-124.260	0.866	-150.521	0.526	0.487	1.013	PT
PT3A	1.013	29.842	0.526	-149.124	0.487	-151.276	0.888	0.025	0.866	PT
DELTA	0.888	30.195	0.025	-124.260	0.866	-150.521	0.526	0.487	1.013	PT
JB78	0.999	0.808	0.978	-121.051	0.961	120.977	0.998	0.959	0.981	
JJB78	1.000	0.621	0.979	-120.920	0.967	120.955	0.997	0.963	0.985	
GEN7	1.013	29.843	0.526	-149.351	0.487	-151.029	0.889	0.024	0.866	UN7

B R A N C H C U R R E N T S

----- THE DIRECTION OF CURRENTS ARE FROM SENDING TO RECEIVINGS

BUSBAR		RED PHASE		YELLOW PHASE		BLUE PHASE		AREA-TO-AREA	
FROM	TO	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	AREA	AREA
J72	J73	0.8634	-49.99	16.7844	36.90	16.8533	-146.03	UN7	UN7
J73	J72	0.8634	-49.99	16.7844	36.90	16.8533	-146.03	UN7	UN7
J73	J74	0.8637	-49.99	16.7846	36.90	16.8536	-146.03	UN7	UN7
J74	J73	0.8637	-49.99	16.7846	36.90	16.8536	-146.03	UN7	UN7
J74	JT7	0.8637	-49.99	16.7846	36.90	16.8536	-146.03	UN7	UN7
JT7	J74	0.8637	-49.99	16.7846	36.90	16.8536	-146.03	UN7	UN7
NETE	MAIN00	18.6946	-170.57	2.2243	87.63	18.3693	2.62	UNE	UNE
MAIN00	NETE	18.6946	-170.57	2.2243	87.63	18.3693	2.62	UNE	UNE

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 61 of 121
	IWPRD	01	0001	EL	ST	001	D1	

MAIN00	JTE	8.8550	-161.76	9.1661	75.68	8.6640	-44.84	UNE	UNE
JTE	MAIN00	8.8909	-132.50	8.7104	104.50	8.3994	-12.92		
B78	JT8	1.6663	-155.11	1.8828	76.54	1.5584	-46.47	UNE	UN8
JT8	B78	1.7979	-127.60	1.7036	102.11	1.4740	-9.42		
J83	SE8	0.0000	30.00	0.0000	30.00	0.0000	30.00	UN8	UN8
SE8	J83	0.0000	30.00	0.0000	30.00	0.0000	30.00		
PT3	PT3A	0.0000	30.00	0.0000	30.00	0.0000	30.00	PT	PT
PT3A	PT3	0.0000	30.00	0.0000	30.00	0.0000	30.00		
PT3A	J73	0.0000	30.00	0.0000	30.00	0.0000	30.00	PT	UN7
J73	PT3A	0.0000	30.00	0.0000	30.00	0.0000	30.00		
PT3A	DELTA	0.0000	30.00	0.0000	30.00	0.0000	30.00	PT	PT
DELTA	PT3A	0.0000	30.00	0.0000	30.00	0.0000	30.00		
JB78	B78	10.7735	-154.93	7.5272	-141.36	18.1766	30.64		UNE
B78	JB78	10.7735	-154.93	7.5272	-141.36	18.1766	30.64		
MAIN00	JJB78	10.7682	-155.00	7.5225	-141.27	18.1637	30.64	UNE	
JJB78	MAIN00	10.7682	-155.00	7.5225	-141.27	18.1637	30.64		
JJB78	JB78	10.7707	-154.97	7.5249	-141.31	18.1700	30.64		
JB78	JJB78	10.7707	-154.97	7.5249	-141.31	18.1700	30.64		
3GEN7	GEN7	1.8906	11.28	10.1234	-138.21	8.5487	48.24	UN7	UN7
GEN7	3GEN7	1.8906	11.28	10.1234	-138.21	8.5487	48.24		
GEN7	J72	0.8761	-50.12	16.7843	36.93	16.8522	-146.05	UN7	UN7
J72	GEN7	0.8761	-50.12	16.7843	36.93	16.8522	-146.05		

SUBSTATION/S FEEDINGS CURRENTS

BUSBAR		RED PHASE		YELLOW PHASE		BLUE PHASE	
FROM	TO	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)
3GEN7	GEN7	1.8906	11.28	10.1234	-138.21	8.5487	48.24
GEN7	3GEN7	1.8906	11.28	10.1234	-138.21	8.5487	48.24
GEN7	J72	0.8761	-50.12	16.7843	36.93	16.8522	-146.05
J72	GEN7	0.8761	-50.12	16.7843	36.93	16.8522	-146.05




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXX						
Document Title	DOCUMENT No							Page 62 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure AIII.5, shows the same result as the previous for LLG fault study by impedance of 0.012 P.U. Unfortunately, the PASHA program is not capable of considering the fault impedance between the two phases and to ground simultaneously and neither can put the ground portion of the fault in another location as it happened in the actual system, in the present time.

TWO LINE-GROUND GENERATOR INTERNAL FAULT GENERATOR INTERNAL FAULT AT T= 0.0ms





	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Table AIII.2, shows the same result as the previous for LLG fault study by impedance of 0.012 P.U. Unfortunately, the PASHA program is not capable of considering the fault impedance between the two phases and to ground simultaneously and neither can put the ground portion of the fault in another location as it happened in the actual system, at its present version.

UNBALANCED FAULT STUDY RESULTS

=====

SYSTEM TITLE : X 3GENERATOR
STUDY TITLE :
FAULT IMPEDANCE (R AND X) = 0.0000 0.0120 PU
TIME AFTER FAULT INCIDENCE = 0.00 MSEC

LINE TO LINE TO GROUND

-INTERNAL FAULT IN GENERATOR

WINDING PERCENT FROM TERMINAL

PHASE B: 88. PHASE C: 75.

	RED PHASE		YELLOW PHASE		BLUE PHASE	
	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)
NEUTRAL SIDE	1.0663	10.34	6.7126	9.58	7.7785	-170.32
TERMINAL SIDE	1.0663	10.34	20.3729	-169.93	19.3075	10.14

-B U S B A R A C V O L T A G E S

BUSBAR	RED PHASE		YELLOW PHASE		BLUE PHASE		PHASE TO PHASE			AREA
	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	MAG (PU)	MAG (PU)	
3GEN7	1.416	34.884	0.202	-76.569	0.244	148.302	0.867	0.238	0.883	UN7
J72	1.416	34.874	0.201	-76.649	0.243	148.259	0.867	0.237	0.883	UN7
J73	1.416	34.868	0.202	-76.534	0.245	148.112	0.867	0.239	0.883	UN7
J74	1.416	34.862	0.204	-76.420	0.246	147.965	0.867	0.240	0.883	UN7
JT7	1.416	34.856	0.205	-76.308	0.247	147.820	0.867	0.242	0.883	UN7
NETE	0.997	0.739	0.981	-120.431	0.972	120.960	0.995	0.970	0.986	UNE
GENE	0.987	37.303	0.966	-82.365	0.981	158.523	0.975	0.969	0.990	UNE
JE2	0.987	37.277	0.966	-82.392	0.981	158.497	0.975	0.969	0.990	UNE
JE3	0.987	37.268	0.966	-82.401	0.981	158.489	0.975	0.969	0.990	UNE
JE4	0.987	37.260	0.966	-82.410	0.981	158.480	0.975	0.969	0.990	UNE
MAIN00	0.997	0.751	0.981	-120.426	0.972	120.968	0.995	0.970	0.985	UNE
PT3	0.867	42.081	0.239	-51.996	0.883	-153.585	0.529	0.554	1.001	PT
PT3A	1.001	34.177	0.529	-122.828	0.554	-167.703	0.867	0.239	0.883	PT
DELTA	0.867	42.081	0.239	-51.996	0.883	-153.585	0.529	0.554	1.001	PT
JB78	0.996	0.957	0.981	-120.474	0.967	121.035	0.995	0.966	0.982	
JJB78	0.997	0.762	0.981	-120.429	0.971	120.971	0.995	0.969	0.985	
GEN7	1.416	34.876	0.201	-76.678	0.243	148.297	0.867	0.237	0.883	UN7

B R A N C H C U R R E N T S

----- THE DIRECTION OF CURRENTS ARE FROM SENDING TO RECEIVINGS

BUSBAR		RED PHASE		YELLOW PHASE		BLUE PHASE		AREA-TO-AREA	
FROM	TO	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)		
J72	J73	1.6448	11.58	12.0452	33.00	13.5865	-149.40	UN7	UN7



**X III HYDRO POWER GENERATION PLANT
UNIT 7 GENERATOR DAMAGE**



XXXXXXXX

Document Title	DOCUMENT No							Page 64 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

J73	J72	1.6448	11.58	12.0452	33.00	13.5865	-149.40		
J73	J74	1.6404	11.90	12.0442	33.05	13.5870	-149.44	UN7	UN7
J74	J73	1.6404	11.90	12.0442	33.05	13.5870	-149.44		
J74	JT7	1.6404	11.90	12.0447	33.05	13.5875	-149.44	UN7	UN7
JT7	J74	1.6404	11.90	12.0447	33.05	13.5875	-149.44		
B78	JT8	2.8498	-158.50	3.0229	77.84	2.7768	-43.48	UNE	UN8
JT8	B78	2.9127	-129.42	2.8450	105.82	2.6699	-10.52		
J83	SE8	0.0000	30.00	0.0000	30.00	0.0000	30.00	UN8	UN8
SE8	J83	0.0000	30.00	0.0000	30.00	0.0000	30.00		
PT3	PT3A	0.0000	30.00	0.0000	30.00	0.0000	30.00	PT	PT
PT3A	PT3	0.0104	126.53	0.0104	126.53	0.0104	126.54		
PT3A	J73	0.0104	126.53	0.0104	126.53	0.0104	126.54	PT	UN7
J73	PT3A	0.0104	126.53	0.0104	126.53	0.0104	126.54		
PT3A	DELTA	0.0000	30.00	0.0000	30.00	0.0000	30.00	PT	PT
DELTA	PT3A	0.0000	30.00	0.0000	30.00	0.0000	30.00		
JB78	B78	10.9887	-158.32	3.3721	-162.18	14.3549	20.78		UNE
B78	JB78	10.9887	-158.32	3.3721	-162.18	14.3549	20.78		
MAIN00	JJB78	10.9851	-158.37	3.3657	-162.05	14.3454	20.77	UNE	
JJB78	MAIN00	10.9851	-158.37	3.3657	-162.05	14.3454	20.77		
JJB78	JB78	10.9867	-158.34	3.3685	-162.11	14.3497	20.77		
JB78	JJB78	10.9867	-158.34	3.3685	-162.11	14.3497	20.77		
3GEN7	GEN7	2.6314	22.68	8.5484	-129.98	6.3261	61.02	UN7	UN7
GEN7	3GEN7	2.6314	22.68	8.5484	-129.98	6.3261	61.02		
GEN7	J72	1.6489	11.23	12.0436	33.02	13.5852	-149.42	UN7	UN7
J72	GEN7	1.6489	11.23	12.0436	33.02	13.5852	-149.42		

SUBSTATION/S FEEDINGS CURRENTS

BUSBAR		RED PHASE		YELLOW PHASE		BLUE PHASE	
FROM	TO	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)
3GEN7	GEN7	2.6314	22.68	8.5484	-129.98	6.3261	61.02
GEN7	3GEN7	2.6314	22.68	8.5484	-129.98	6.3261	61.02
GEN7	J72	1.6489	11.23	12.0436	33.02	13.5852	-149.42
J72	GEN7	1.6489	11.23	12.0436	33.02	13.5852	-149.42



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Table AIII.3, shows the result of the fault study when R phase in slot 127 is connected to the T phase in slot 126 (R to the neutral point). According to the section 5 this fault is not the initial two phase fault.

UNBALANCED FAULT STUDY RESULTS

=====

SYSTEM TITLE : X 3GENERATOR
STUDY TITLE :
FAULT IMPEDANCE (R AND X) = 0.0000 0.0000 PU
TIME AFTER FAULT INCIDENCE = 0.00 MSEC

LINE TO LINE

-INTERNAL FAULT IN GENERATOR

WINDING PERCENT FROM TERMINAL

PHASE B: 0. PHASE C: 100.

	RED PHASE		YELLOW PHASE		BLUE PHASE	
	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)
NEUTRAL SIDE	12.0325	-143.20	28.0628	36.62	16.0305	-143.51
TERMINAL SIDE	12.0325	-143.20	12.1212	-143.18	24.1537	36.81



-BUSBAR AC VOLTAGES

BUSBAR	RED PHASE		YELLOW PHASE		BLUE PHASE		PHASE TO PHASE			AREA
	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	MAG (PU)	MAG (PU)	
3GEN7	0.885	56.362	0.875	-110.287	0.205	155.989	1.009	0.526	0.544	UN7
J72	0.885	56.363	0.875	-110.302	0.205	155.955	1.009	0.526	0.543	UN7
J73	0.885	56.305	0.875	-110.258	0.206	155.928	1.009	0.526	0.544	UN7
J74	0.885	56.248	0.875	-110.214	0.208	155.901	1.009	0.527	0.544	UN7
JT7	0.885	56.191	0.875	-110.170	0.209	155.875	1.009	0.527	0.545	UN7
PT3	1.009	62.983	0.526	-97.222	0.544	-136.157	0.875	0.206	0.885	PT
PT3A	0.885	56.305	0.875	-110.258	0.206	155.928	1.009	0.526	0.544	PT
DELTA	1.009	62.983	0.526	-97.222	0.544	-136.157	0.875	0.206	0.885	PT
JB78	0.985	1.243	0.999	-120.338	0.968	119.726	1.000	0.983	0.969	
JJB78	0.988	1.073	0.998	-120.392	0.971	119.816	1.001	0.984	0.973	
GEN7	0.885	56.377	0.875	-110.313	0.204	155.961	1.009	0.526	0.543	UN7

BRANCH CURRENTS

----- THE DIRECTION OF CURRENTS ARE FROM SENDING TO RECEIVINGS



BUSBAR		RED PHASE		YELLOW PHASE		BLUE PHASE		AREA-TO-AREA	
FROM	TO	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)		
J72	J73	8.8331	58.39	6.7112	67.65	15.4945	-117.61	UN7	UN7
J73	J72	8.8331	58.39	6.7112	67.65	15.4945	-117.61		
J73	J74	8.8333	58.39	6.7113	67.65	15.4948	-117.61	UN7	UN7
J74	J73	8.8333	58.39	6.7113	67.65	15.4948	-117.61		
J74	JT7	8.8334	58.39	6.7112	67.65	15.4948	-117.61	UN7	UN7
JT7	J74	8.8334	58.39	6.7112	67.65	15.4948	-117.61		
MAIN00	NETE	19.4671	-149.62	12.0999	48.07	8.7500	5.52		
MAIN00	JTE	8.7022	-162.73	9.1056	77.65	8.9615	-44.77	UNE	UNE

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 66 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

JTE	MAIN00	8.6598	-131.78	8.9073	106.19	8.5159	-14.25		
MAIN00	JJB78	14.0868	-125.51	3.1302	41.24	11.0632	58.21	UNE	
JJB78	MAIN00	14.0868	-125.51	3.1302	41.24	11.0632	58.21		
JJB78	JB78	14.0918	-125.50	3.1281	41.35	11.0687	58.19		
JB78	JJB78	14.0918	-125.50	3.1281	41.35	11.0687	58.19		
3GEN7	GEN7	3.5429	-91.65	5.4121	-114.31	8.7882	74.63	UN7	UN7
GEN7	3GEN7	3.5429	-91.65	5.4121	-114.31	8.7882	74.63		
GEN7	J72	8.8329	58.31	6.7110	67.75	15.4922	-117.61	UN7	UN7
J72	GEN7	8.8329	58.31	6.7110	67.75	15.4922	-117.61		

SUBSTATION/S FEEDINGS CURRENTS

BUSBAR		RED PHASE		YELLOW PHASE		BLUE PHASE	
FROM	TO	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)	MAG (PU)	ANG (DEG)
3GEN7	GEN7	3.5429	-91.65	5.4121	-114.31	8.7882	74.63
GEN7	3GEN7	3.5429	-91.65	5.4121	-114.31	8.7882	74.63
GEN7	J72	8.8329	58.31	6.7110	67.75	15.4922	-117.61
J72	GEN7	8.8329	58.31	6.7110	67.75	15.4922	-117.61

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 68 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

III.3 THE RECORDED FAULT CURRENTS AND VOLTAGES

Figure 2 shows the waveforms of the recorded fault currents and voltages. The following magnitude can be brought under consideration:

- Phasor of V_{st} after the two phase fault is approximately: 0.83 P.U.
- Phasor of V_{tr} after the two phase fault is approximately 0.26 P.U.
- Phasor of V_{rs} after the two phase fault is approximately 0.84 P.U.
- Phasor of I_r after the two phase fault is approximately 3.6 P.U.
- Phasor of I_s after the two phase fault is approximately 0.829 P.U.
- Phasor of I_t after the two phase fault is approximately 2.93 P.U.

P.U. base is 15.75KV for voltages and 12500 A for currents.

III.4 INTERPRETATION OF THE RESULTS:

Comparing the results obtained in the previous two sections, will give a clear insight of the fault situation and the magnitudes of the currents as the followings:

(1) A two phase fault occurred between the slots 326 and 327 while the single phase fault in slot 217 was presented. The double phase fault had a fault impedance of approximately 0.01 P.U. inductive (based used in section III.2) and the single phase fault had an impedance of approximately 0.005 P.U. resistive.

(2) The double phase faults in slot 126, and 127 have not occurred till the interruption of the phase T.

(3) The magnitude of the currents is as the followings:

Coming from the source side: 48KA in R phase, 46KA in T phase

The differential relay sees: (the values are read from Table III.2



For R phase $(6.327\angle 61.02 - 7.7785\angle -170.32) - 13.59\angle -149.42 = (12.73\angle 32.52) - 13.08\angle -149.34 = 26.31p.u.$ BASE 3670 A

On 12500A*0.771 is 10.02In as shown by differential relay

For T phase $(8.549\angle -129.98 - 6.7126\angle 9.58) - 12.045\angle 33.03 = 26.38p.u.$ BASE 3670A on 12500*0.771 is 10.05In



For S phase $(2.6315\angle 22.67 - 1.0663\angle 10.33) - 1.648\angle 11.31 = 0.55p.u.$ BASE 3670A on 12500*0.771 is 0.24 In

We did not consider DC decays in all the calculation and the relay has a psequ RMS values while here is the

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
Document Title	DOCUMENT No							Page 69 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

actual RMS. It is worth to mention that the difference of the current in unfaulted phase (i.e. phase S) is due to the mutual influence of the faulted phases in generator internal fault.

Other fault and three phase transient stability (runs) studies (not reported in this document) are all show that the above conclusion would be the best we may reach.

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 70 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX IV

GENERATOR MODELLING FOR FIELD TRANSIENTS

The mathematical representations of the generator model have been widely used as the basic for time domain simulation [5]. A block diagram transfer function model of the generator is represented in here to simulate the behaviour of the field variables during the transients. Figure AIV.1 shows the generator field components. What it is intended in this section, is to simulate the opening of the field under two phases fault condition, in order to find out the transients involved.

IV.1 GENERATOR MODELING

The d-q model of a synchronous generator is represented in the following equations. The equations can be found in many literatures including [1], and [2].

$$V_d = -rI_d - \lambda'd - \omega\lambda_q$$

$$V_q = -rI_q - \lambda'q + \omega\lambda_d$$

$$V_f = -rI_f - \lambda'f$$

$$0 = -r_{kd}I_{kd} - \lambda'kd$$

$$0 = -r_{kq}I_{kq} - \lambda'kq$$

$$\lambda_d - \lambda_{AD} = l_d I_d$$

$$\lambda_q - \lambda_{AQ} = l_q I_q$$

$$\lambda_f - \lambda_{AD} = l_f I_f$$

$$\lambda_{kd} - \lambda_{AD} = l_{kd} I_{kd}$$

$$\lambda_{kq} - \lambda_{AQ} = l_{kq} I_{kq}$$



$$\lambda_{AD} = L_{AD}(I_d + I_f + I_{kd}) = L_{MD}(\lambda_d / l_d + \lambda_f / l_f + \lambda_{kd} / l_{kd})$$

$$\lambda_{AQ} = L_{AQ}(I_q + I_{kq}) = L_{MQ}(\lambda_q / l_q + \lambda_{kq} / l_{kq})$$

$$1 / L_{MD} = 1 / l_d + 1 / l_f + 1 / l_{kd} + 1 / L_{AD}$$

$$1 / L_{MQ} = 1 / l_q + 1 / l_{kq} + 1 / L_{AQ}$$

The following base quantities are used:

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 71 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Stator Base Quantities: In the equations

$$S_{base} = 263 / 3 MVA$$

$$V_{base} = 15.75 KV / 1.732$$

$$I_{base} = 9641 A$$

$$Z_{base} = 0.943 Ohm$$

$$W_{base} = 314.1516 Rad / Sec$$

$$L_{base} = 3.0 mH$$

Rotor Base Quantities are:

$$S_{fbase} = 87.7 MVA$$

$$V_{fbase} = 176 KV$$

$$I_{fbase} = 498.1 A$$

$$Z_{fbase} = 353.34 Ohm$$

$$L_{fbase} = 1.124 H$$

$$C_{fbase} = 0.125 \mu F$$

$$Y_{fbase} = 0.004 \sigma hm$$

The following parameters in P.U. can be derived [1] from machine sub transient and transient data which are written in input data list:

$$r = 0.0025$$

$$l_d = l_q = 0.191$$

$$LAD = 1.065 - 0.191 = 0.874$$

$$LAQ = 0.656 - 0.191 = 0.465$$

$$l_f = 0.062$$

$$l_{kd} = 0.12$$

$$l_{kq} = 0.0426$$

$$L_f = 0.936$$

$$L_{kd} = 0.993$$

$$L_{kq} = 0.5076$$



$$r_f = 0.000281 * \text{effect - of - heating}$$

$$r_{kd} = 0.0121$$

$$LMD = 0.0324$$

$$LMQ = 0.135$$

$$r_{kq} = 0.06$$

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 72 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

IV.1.1 Field discharge resistor

A 1300V, 6750A, 3564KJ, nonlinear resistor is used in the field to discharge the field current and prevent the overvoltages of the field breaking.

Document M26412A/02 shows the V-I characteristic of this nonlinear resistor. The following relationship can be extracted from this logarithmic characteristic:

AC waveforms:

$$IR = 0.0000032 * Vf^3 \text{ Amper} - \text{Volt}$$

$$IR = 13,162,300.4 * Vf^3 \text{ P.U.}$$

DC waveforms:

$$IR = 0.000000450832 * Vf^{2.7} \text{ Amper} - \text{Volt}$$

$$IR = 5,458,278.9 * Vf^{2.7} \text{ P.U.}$$

IV.1.1 Field capacitance

A capacitance exists between any two conductors or a conductor and the earth or a conductor and a charged/neutralized plate.

The field circuit capacitance magnitude between the positive and negative conductors can be extracted from generator open circuit tests – field discharge tests in emergency mode.

The following relationship applies: where 1/C is equal 0.25 P.U.

$$I_{cb} = IR + IC - I_f$$

$$V_f = 1 \setminus C \int I_{cdt}$$






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX														
	Document Title CAUSES OF THE DAMAGE	DOCUMENT No <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">PHASE</th> <th style="width: 10%;">AREA</th> <th style="width: 10%;">TRAIN/ UNIT</th> <th style="width: 10%;">DIS</th> <th style="width: 10%;">DOC</th> <th style="width: 10%;">SEQ</th> <th style="width: 10%;">REV</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">IWPRD</td> <td style="text-align: center;">01</td> <td style="text-align: center;">0001</td> <td style="text-align: center;">EL</td> <td style="text-align: center;">ST</td> <td style="text-align: center;">001</td> <td style="text-align: center;">D1</td> </tr> </tbody> </table>							PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	IWPRD	01	0001	EL	ST	001	D1
PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV																
IWPRD	01	0001	EL	ST	001	D1																

Figure AIV.1 Field circuit schematic



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							
CAUSES OF THE DAMAGE	PHASE IWPRD	AREA 01	TRAIN/ UNIT 0001	DIS EL	DOC ST	SEQ 001	REV D1	Page 74 of 121

IV.1.3 Block diagram transfer function model

A block diagram transfer function model of the above equations is constructed using UDEM (User Defined Equipment Modelling) of PASHA program. Logical switch elements are used to simulate the switching behaviour of the field and omit those equations not needed during the simulation. The block diagram transfer function constructed is shown in figures AIV.2.






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No PHASE AREA TRAIN/UNIT DIS DOC SEQ REV IWRD 01 0001 EL ST 001 D1					

Figure AIV.2 block diagram transfer function model of the generator and its field:



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 76 of 121
	IWPRD	01	0001	EL	ST	001	D1	

IV.2 Testing the generator model

1) The generator is subjected to a three phase fault in PASHA fault analysis when generator is operating at no load condition with the terminal voltage of 0.4917. This test has been done to be ensured about the actual plant test results.

Generator UDEM model shown in figure AIV.2 is subjected to the following tests:

- 2) Field opening in emergency shut down mode, when generator is operating at no load condition with the terminal voltage of 1.0 P.U.
- 3) Short circuit test, again the generator is operating in no load condition, with terminal voltage of 0.4917

The result of dynamic fault analysis for case 1 is shown in figure IV.3. The results of case 2 above are shown in Figures AIV.4 and AIV.5. The results of the site tests for the above cases are shown in Figures AIV.6, and AIV.7. The results are in close agreement; therefore, the generator model is valid, however, some might notice that the magnitude of the overvoltage written for fault opening is not correct when the generator was in the site test.

IV.3 Opening the field under full load

Having a correct model, for field opening, figure AIV.8, shows the interruption of the field under full load condition. The overvoltage arise in the field will go to 790V.

IV.3 Opening the field under fault condition



Figure AIV.9 shows the results of three phase fault of the generator without field opening in the full load condition, the amount of field overvoltage is 1192V.

Figures AIV.10 and AIV.11 show the same results while the controlling diodes of the discharging resistor are damaged when the voltage goes above 1100V, and after some milliseconds the field has been opened by field circuit breaker (and so resistor came in). The amount of overvoltage depends to the magnitude of field current when the field circuit breaker interrupts the circuits involved. Here, for some examples it is between 9 to 10KV.

IV.4 Opening the field under two phase fault condition

D-q model of the generator is valid for balanced operation or three phase fault studies. However, if the current of the unfaulted phase is ignored, it will be valid under two phase fault too.

Figure AIV.12 shows the same situation for fault opening as figure AIV.10 when two phase fault are applied.

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
Document Title	DOCUMENT No							
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 77 of 121
	IWPRD	01	0001	EL	ST	001	D1	

IV.5 sub-conclusion

In conclusion the controlling diodes of the field are mostly responsible for the damages came inside the field, because of high overvoltages around 10KV between two poles and around 5KV respect to ground.

In the actual situation of the events as described in section 5, this overvoltage has produced an arc between the field circuit breaker and the plates around the field circuits. One picture is shown in Figure 2. The same overvoltage damaged the field winding number 25.

The high magnitude overvoltage at the other side of the field circuit breaker is passed through the field circuit breaker. This overvoltage caused the thyristors and their controllers to be damages. The damages of the thyristors might also be because of the earth arc into the cabinet as described in Elin reports. The important point is that; from this instant of time the excitation transformer is short circuited in the secondary thought Thyristor Bridge.

Figure AIV.13 shows the thyristors which are damages.




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 78 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Figure AVI.3(a) Three phase fault in PASHA fault analysis when generator is operating at no load condition with the terminal voltage of 0.4917. This is done in order to get ensure about the test results. Saturation is considered.






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 79 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Figure AVI.3(b) Three phase fault in PASHA fault analysis when generator is operating at no load condition with the terminal voltage of 0.4917. This is done in order to get ensure about the test results. Without saturation, base as figure AVI.3 (a)






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX														
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No <table border="1" style="width: 100%; text-align: center;"> <tr> <th>PHASE</th> <th>AREA</th> <th>TRAIN/ UNIT</th> <th>DIS</th> <th>DOC</th> <th>SEQ</th> <th>REV</th> </tr> <tr> <td>IWPRD</td> <td>01</td> <td>0001</td> <td>EL</td> <td>ST</td> <td>001</td> <td>D1</td> </tr> </table>						PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	IWPRD	01	0001	EL	ST	001	D1
PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV																
IWPRD	01	0001	EL	ST	001	D1																

Figure AIV.4 simulation results, emergency opening of the field circuit breaker, field voltage (V)

UDEM PLOT OF ELEMENT OUTPUTS IN (%)



COPYRIGHT (C) TOM InC 1988 TIME : 09:02:22 07/12/2007





	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 81 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Figure AIV.5 simulation results, three phase short circuit of the stator, generator was operating at no load condition with 0.4917 terminal voltages. Saturation is not considered, if wants, multiply the terminal current values on 0.23/0.2.


UDEM PLOT OF ELEMENT OUTPUTS IN KAR5
Graph 1: UDEM Module KAR5



Graph 3: UDEM Module KAR5



Graph 2: UDEM Module KAR5



GRAPH 1		GRAPH 2		GRAPH 3		
ELEMENT	SCALING	ELEMENT	SCALING	ELEMENT	SCALING	
TRACE	NUMBER	FACTOR	NUMBER	FACTOR	NUMBER	FACTOR
—	41	930.48	36	8.54	33	50.92
—		Field Voltage Volt		Field current p.u. * 498A		Terminal current KA
—						Saturation not considered

COPYRIGHT (C) TOM InC 1988 TIME : 09:19:10 07/12/2007




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title CAUSES OF THE DAMAGE	DOCUMENT No						
	PHASE IWPRD	AREA 01	TRAIN/ UNIT 0001	DIS EL	DOC ST	SEQ 001	REV D1	

Figure AIV.6 actual test results, emergency opening of the field circuit breaker







	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 83 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure AIV.7 actual test results, three phase short circuit of the stator, generator was operating in no load condition with 0.4917 terminal voltages






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 84 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure AIV.8; simulation result of emergency field opening under full load condition

UDEM PLOT OF ELEMENT OUTPUTS IN (%)



COPYRIGHT (C) TOM InC 1988 TIME : 09:24:10 07/12/2007





	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 85 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Figure AIV.9 simulation results, three phase short circuit of the stator, generator was operating at full load condition with 1.0P.U. terminal voltages. Saturation is not considered, if wants, multiply the terminal current values on 0.23/0.2.


UDEM PLOT OF ELEMENT OUTPUTS IN KAR5
Graph 1: UDEM Module KAR5



Graph 3: UDEM Module KAR5



Graph 2: UDEM Module KAR5



TRACE	GRAPH 1		GRAPH 2		GRAPH 3	
	ELEMENT NUMBER	SCALING FACTOR	ELEMENT NUMBER	SCALING FACTOR	ELEMENT NUMBER	SCALING FACTOR
—	41	1192.52	36	19.20	33	111.16
—						
—						
—						

COPYRIGHT (C) TOM InC 1988 TIME : 09:29:02 07/12/2007






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 86 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Figure AIV.10 simulation results, three phase short circuit of the stator, generator was operating at full load condition with 1.0P.U. terminal voltages. Saturation is not considered, if wants, multiply the terminal current values on 0.23/0.2. The controlling diodes are damaged in 0.15 Sec. with 1100V



ELEMENT SELECTION

TRACE	GRAPH 1		GRAPH 2		GRAPH 3	
	ELEMENT NUMBER	SCALING FACTOR	ELEMENT NUMBER	SCALING FACTOR	ELEMENT NUMBER	SCALING FACTOR
—	41	11789.39	36	19.21	33	111.20
—		Field Voltage Volt		Field current p.u. * 498A		Terminal current KA
—						Saturation not considered

COPYRIGHT (C) TOM InC 1988 TIME : 09:35:00 07/12/2007






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure AIV.11 simulation results, three phase short circuit of the stator, generator was operating at full load condition with 1.0P.U. terminal voltages. Saturation is not considered, if wants, multiply the terminal current values on 0.23/0.2. The controlling diodes are damaged in 0.143 Sec. with 1100V



ELEMENT SELECTION		GRAPH 1		GRAPH 2		GRAPH 3	
TRACE	NUMBER	ELEMENT	SCALING FACTOR	ELEMENT	SCALING FACTOR	ELEMENT	SCALING FACTOR
—	41	Field Voltage Volt	9500.05	36	19.21	33	111.20
—					* 498A		
—							KA
—							Saturation not considered

COPYRIGHT (C) TOM InC 1988 TIME : 09:54:28 07/12/2007






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 88 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Figure AIV.12 simulation results, two phase short circuit of the stator, generator was operating at full load condition with 1.0P.U. terminal voltages. Saturation is not considered, if wants, multiply the terminal current values on 0.23/0.2. The controlling diodes are damaged in 0.15 Sec. with 1100V and some oscillation during the damage.



ELEMENT SELECTION

TRACE	GRAPH 1		GRAPH 2		GRAPH 3	
	ELEMENT NUMBER	SCALING FACTOR	ELEMENT NUMBER	SCALING FACTOR	ELEMENT NUMBER	SCALING FACTOR
—	41	5166.89	36	15.72	33	116.83
—		Field Voltage Volt		Field current p.u		Terminal current KA
—				* 498A		Saturation not considered

COPYRIGHT (C) TOM InC 1988 TIME : 10:34:00 07/12/2007






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX														
	Document Title CAUSES OF THE DAMAGE	DOCUMENT No <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 12.5%;">PHASE</th> <th style="width: 12.5%;">AREA</th> <th style="width: 12.5%;">TRAIN/ UNIT</th> <th style="width: 12.5%;">DIS</th> <th style="width: 12.5%;">DOC</th> <th style="width: 12.5%;">SEQ</th> <th style="width: 12.5%;">REV</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">IWPRD</td> <td style="text-align: center;">01</td> <td style="text-align: center;">0001</td> <td style="text-align: center;">EL</td> <td style="text-align: center;">ST</td> <td style="text-align: center;">001</td> <td style="text-align: center;">D1</td> </tr> </tbody> </table>							PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	IWPRD	01	0001	EL	ST	001	D1
PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV																
IWPRD	01	0001	EL	ST	001	D1																

Figure AIV.13 Thyristors damages:



- * Thyristors V1, V2, V3, V4, V6 are damaged (shorted)
- * Thyristor Fuses L2+ (V2) and L1- (V4) are damaged!

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 90 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX V

FAST TRANSIENT SWITCHING

Opening an inductive circuit in the presence of capacitance will produce over voltages in many situations [1]. In our case when phase T is opening, since it is already grounded through the single phase fault, there would be no such a transient. But when the phase R is going to be opened by GCB at the instant of current zero the source side voltage would be in its maximum. The ferroresonance of the PT in the source side and the portion of the generator inductance which is already grounded through phase T in the generator side would impose a very difficult duty for GCB to open the fault in current zero. Some restriking may take place and the current chopping would be the consequences.

Figure AV.1 shows a simplified situation of the above opening. Figure AV.2 shows the Red phase current. It seems that in the vicinity of the current zero some current chopping and restriking have taken place. A clear insight of the restriking cannot be seen in the figures because of CT magnetic delays, but the way that the current is going to zero will show such a condition.

However, without current chopping an overvoltage with the frequency of 13.4KHZ ($L_2=0.57\text{mH}$, and $C_2=0.25\ \mu\text{F}$) and 15.3 KHZ ($L_1=0.4\text{mH}$, and $C_1=270\text{nF}$) in the generator side will occur. The magnitude of overvoltage in the generator side would be calculated from the following formula: (please refer to the reference for details)

$V_{c2}(t) = 1 + 1.35\cos\omega_1 t + 2.36\cos\omega_2 t$, this is shown in figure AV.3

The maximum is about 4.5 P.U.

Therefore, if the current chopping has not been occurred the value is around 57.7KV ($4.5 \times 15.75 \times 1.41 / 1.732$) and if chopping of 800 Amper (from the figure this seems to be 3400A) has been made this would be around 54KV ($0.5L_1 \omega_1^2 = 0.5C_1 v_1^2$). Due to distributed nature of the generator capacitance and the mutual effect of the reactances, more elaborate analysis must be done for overvoltages in the vicinity of generators [2], which is out of the scope of this report. Even in this simple analysis we have not considered the back EMF in phase R which is quite out of phase with the source voltage at the instant of opening. This may bring overvoltages to 1.25 times of the values that are just mentioned. For the calculations made please refer to the formula available in section 3.4 of the reference.

The high frequent overvoltage of phase R in the generator side have caused the discharge capacitor of CC2 which was the nearest one to blow up and the other discharge capacitors in this phase for the other windings just to get harmed (because of their distance and the damping effect in the circuits involved). Its current has been passed through grounded faulted point of slot 217 and made the surroundings coppers scattered. It also paths through the nearest earth in the metal cover and brought damages to the outgoing plates. The high frequency shocks had caused the complete destruction of oil mist distracter and its other belongings.




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 91 of 121
CAUSES OF THE DAMAGE	PHASE IWPRD	AREA 01	TRAIN/ UNIT 0001	DIS EL	DOC ST	SEQ 001	REV D1	

Figure AV.1 Interruption of phase R situation and the faults are in the windings 2U and 3W.





	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 92 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Figure AV.2 Current interruption







Figure V.3 Overvoltage in the generator side, time 0.002 sec



COPYRIGHT (C) TOM InC 1988 TIME : 05:00:59 28/11/2007

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXX						
Document Title	DOCUMENT No							Page 93 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX VI

ARCING GROUND PHENOMENA

The arcing ground has been the subject of much discussion from time to time. Figure AVI. 1 shows the sequence of events which occurs when an earth fault on insulated neutral system is not well established. In this case a fault to earth causes so little current to flow that the arc is extinguished and the system is restored to healthy condition. This was however the condition which leads to the fault, which then re-appears. As the phase rotates the possibility exists that current flow will cease at a natural zero, which in an inductive system occurs at a voltage maximum. Charge is trapped on the system and all three phases gradually move away from the balanced condition centered about zero voltage until another fault occurs (for more information about this phenomenon, please refer to the note attached which is written in Farsi).

In high resistance earthing a high value resistor is chosen, as high as possible whilst retaining the ability to prevent arcing grounds. The arcing ground builds up at its most rapid steps every half cycle and the provision of earthing resistor gives a path for the discharge of the trapped charge. If the time constant of the RC combination is held to a value of one radian is $1/314.1516$ sec, the over voltages will effectively be prevented from building up. To achieve this $3R$ in the zero phase sequence must, when multiplied by C , give a value of $1/314.1516$. Hence $R = Xc / 3$ where $Xc = 1/314.1516 * C$. The resistor thus equals in ohmic value the total capacitance of all three phases to earth. The value is likely to be some thousands of ohms and such a resistor is difficult to make in reliable form, and hence, a single phase transformer is used to step up the current and reduce the voltage so that the resistor becomes much more robust. Most large generators including our generator are earthed by this system.

According to ELIN document 3-539 304, the following capacitance are recognized for the system:

Generator $C_{gen} = 0.97 \mu F/phase$

Transformer:

$C_{Tr HV-LV} = 2.6 nF$

$C_{Tr HV-Gnd} = 1.3 nF$

$C_{Tr LV-Gnd} = 11 nF$



IPB: $C_{IPB-Gnd} = 6.9 nF$ (0.063 nF/m/phase, 110m)

Generator CB: 130 nF Generator side
260 nF Transformer side

St. Serv. Transf: Capacitance value not known (ABB supply)!

Total three phase capacitance 4.13 μF

Therefore, the capacitor Xc is $1/4.13 * 10^{-6} * 314.1516 = 770.75 \text{ Ohm}$

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
Document Title	DOCUMENT No							Page 94 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

The resistor is selected to be 0.59 Ohm in the secondary side of a single phase transformer with the following characteristic:

16KVA, 9.09 / 0.24KV

Therefore, if we view the resistor from primary side the magnitude is $0.59 \times 9.09^2 / 0.24^2 = 846.36$ Ohm

The value does not match the requirements for the grounding resistor; however, the value of 0.54 Ohm (having not known the St. Serv. Tranf. Capacitance) was a better choice. Do not treat this value as a recommendation; it is not the intention of this report to recommend any value.

According to the mentioned ELIN document, this produce 100% voltage displacement in an earth fault condition.

AVI. 1 TESTING THE EARTHING TRANSFORMER

A test has been conducted on the earthing transformer to find out its saturation characteristics. Figure AVI.2 shows the result of the test. The results are summarized in table AVI. 1.

In a single phase fault condition the neutral voltage will give rise to 1.01 P.U. (to the voltage of the system prior to the fault) this is more than 240V. The result shows that there is no significant saturation in this situation. However, when considering the ferroresonance of PT described in the next appendix which will also produce overvoltages, and bearing in mind that the earthing transformer can also contribute to a ferroresonance effect, it is obvious that the selected transformer cannot properly handle its job and prevent the arcing ground phenomenon.




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No					
	PHASE IWPRD	AREA 01	TRAIN/ UNIT 0001	DIS EL	DOC ST	SEQ 001	REV D1	

Figure AVI.2. Testing the earthing transformer:







	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Table AVI.1. Test results

Voltage applied to the secondary side (V)	Current (A)	Calculated magnetizing reactance (Ohm)	Voltage applied to the secondary side (V)	Current (A)	Calculated magnetizing reactance (Ohm)		
20	0.03	666.67	350	1.02	343.14		
30	0.04	750.00	360	1.18	305.08		
50	0.06	833.33	370	1.35	274.07		
60	0.08	750.00	380	1.53	248.37		
75	0.1	750.00	400	1.94	206.19		
100	0.12	833.33	410	2.2	186.36		
125	0.15	833.33					
150	0.19	789.47					
175	0.22	795.45					
200	0.26	769.23					
225	0.29	775.86					
240	0.32	750.00					
250	0.34	735.29					
260	0.37	702.70					
270	0.4	675.00					
280	0.42	666.67					
290	0.46	630.43					
300	0.51	588.24					
310	0.57	543.86					
320	0.65	492.31					
330	0.76	434.21					
340	0.88	386.36					

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
Document Title	DOCUMENT No							Page 97 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX VII

FERRO RESONANCE EFFECTS

The application of grounded Y potential transformers on ungrounded systems with a Y or/and broken delta connection can be responsible for damaging over voltages as a result of resonant or ferroresonant action since the magnetizing reactance of the potential transformers becomes connected from phase conductor to ground. A complete description of this phenomenon need not be taken up here as it has been adequately treated in the literatures [2],[3],[4].

The ferroresonance would not be occurred if the electric system neutral is effectively grounded. Freedom from this particular type of phenomenon can be obtained even with ungrounded neutral operation by following the IEEE recommendations:

- 1- Select PT with line-to-line rated voltage. In our case the PT must be 15.75*1.73205KV in the primary side.
- 2- Apply a secondary loading resistor with a resistance not greater than 40 percent of the transformer magnetizing reactance. Please refer to the following test results to find out our plant situations.

As stated we are not going to provide a full scale simulation of this phenomenon in this report. The obvious consequences of the PT resonance in the system, is the amount of zero sequence current feeding to the single phase fault in the generator. From the results obtained in Appendix II (table II.2), it can be recognized that an oscillatory zero sequence current of magnitude 27-202A has been injected toward single phase fault point as the result of the occurrence of this phenomena. Note that the 3I0 reading numerical errors is $0.003*12500=37.5A$.

Figure 2 shows the records of the system variables. The PT3-RS record is indeed the voltage of the phase T respect to phase S measured in the secondary of the potential transformer. There are two confusing measurement in respect to the waveform:

- 1- It does not show the system potential after GCB opening. This was found to be due to the opening of the secondary miniature fuses as the result of resonance. Test conducted shows the resonance noise heard from the transformer and the opening of this miniature fuse when the voltage applied to the secondary was more than 60V (110/1.73205) has happened in the test. Relay 64GB has gone in off position at time 183 msec, (so it sees the PT3 resonance until this time and considering the existence of low voltage Vts after this time) it suggest that the corresponding miniature has been opened at this time.

- 2- Before occurrence of the two phases fault, it has an angle division in respect to the voltage of phase T to S (the -180 degree shifted can be read from PT1 on the voltage ST, obtained from the zero crossing points 7.2 degree (0.4 msec $0.4*360/20$)). This is the result of the reduction of the magnetizing reactance of the transformer which provides a parallel inductive path for the burden, so the phase shift will occur, and proves an overvoltage was presented which is due to a single phase fault in the system. The visual inspections show that a loose connection to the ground is presented in this secondary side too, but it had no effect in the above, it might be occurred because of the above resonance.

The results of handmade test and the loose connection location is indicated in the following figure (figure AVII.1), which also shows the probable faults that might exist inside the PT3. Table AVII.1 shows the result of the test



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title CAUSES OF THE DAMAGE		DOCUMENT No PHASE AREA TRAIN/UNIT DIS DOC SEQ REV IWPRD 01 0001 EL ST 001 D1					

Table AVII.1. The result of test on secondary sides of PT shown below in two occasions

Voltage applied to the star connected secondary V0 (V)	Current of the injected voltage in the star connected secondary (A)	Voltage of open delta connected secondary across resistor (V)	Current of open delta secondary (A)				
10.	0.5	17.73	0.3				
20.2	0.7	34.8	0.41				
30.1	1.1	52.9	0.62				
40.2	1.5	69.9	0.71				
50.02	1.9	87.7	0.93				
60.04	2.4	104	1.2				

Voltage applied to the star connected secondary V0 (V)	Current of the injected voltage in the star connected secondary (A)	Voltage of open delta connected secondary across resistor (V)	Current of open delta secondary (A)				
10	0.5	17.73	0.3				
20	0.8	34.4	0.4				
40	1.5	69.4	0.7				
50	1.8	86.4	0.9				
60	2.7	106.5	1.3				
62	4.5	115.7	2.4				
64	7	120	3.3				

The magnitude of R from secondary side is approximately = 48-90 Ohm during the test or $90 \times 100 / 0.11 \times 0.11 = 743,801$ P.U. in 100MVA base.

The magnitude of X_m is about 86 Ohm from secondary side point of view = 700000P.U. But when as a result of fault in the secondary side the zero flux of the secondary must flow to the air, the X_{m0} will be reduced to a small value. The value can be calculated if the PT core dimensions are considered. However, the zero current flow of appendix II shows that this is about 40 P.U. on 100MVA bases. During this flowing of the zero current the primary side voltages increased and produced a ferroresonance effect.





	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure AVII.1 PT3 connection and test results, primary test





X III HYDRO POWER GENERATION PLANT
UNIT 7 GENERATOR DAMAGE




XXXXXXXXXX

Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV
	IWPRD	01	0001	EL	ST	001	D1

Page 100 of 121

مدار مربوط به تست PT3 :






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 101 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure AVII.2 PT3 connection and test results, tested again






X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE



XXXXXXXX

Document Title	DOCUMENT No							Page 102 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	








X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE



XXXXXXXX

Document Title	DOCUMENT No						Page 103 of 121	
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ		REV
	IWPRD	01	0001	EL	ST	001		D1



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 104 of 121
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX VIII

GENERATOR WINDING CONNECTION

The stator winding is 4 times parallel connected and designed as wave winding. Therefore 4 connection groups, symmetrically distributed on the circumference, exist in NDE. Each of them has one line end and one neutral end per phase and parallel path (Elins report).

Figure AVIII.1 shows a schematic of the winding diagram. Table AVIII.1 shows the same in a tabular form. According to Elins report the damages caused by flash overs are presented on 3 of these 4 connection groups. However, when we follow up the slots, we have found that the damages addressed in the mentioned report are just existed in two connection groups as shown in Figure AVIII.2. This is completely in agreement with the sequence of the events described in section 5.

The other drawback of the Elins report is its emphasis on the melting or replacement of the materials. During the first 70-80 msec, that the GCB opens the fault, there is no time for the replacement of the materials or melting of these materials. All these melting and replacements would take place after this time, as the generator was rotating for about 15 seconds and the internal fault was fed through self excitation of the generator.

In appendix III, we proved that during the first 70msec, the only two phases fault occurred inside the generator windings was the one between slot 326 and 327. The damage in these slots was too low because of the small time that this two phases fault was being in the generator. After GCB opening, the first two phases fault had been extinguished, since other stronger faults are produced in the same windings. The opening overvoltages are responsible for producing the other faults as mentioned in section 5 and described in appendix V.




	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 105 of 121
CAUSES OF THE DAMAGE	PHASE IWRPD	AREA 01	TRAIN/UNIT 0001	DIS EL	DOC ST	SEQ 001	REV D1	

Figure AVIII.1 generator winding diagram





	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Table AVIII.1 Generator winding table: **Single phase fault, Line to Line fault**

Slot No.	Phase T				Phase S				Phase R															
	1W		2W		3W		4W		1V		2V		3V		4V		1U		2U		3U		4U	
	L	R	L	R	L	R	L	R	L	R	L	R	L	R	L	R	L	R	L	R	L	R	L	R

217					1	33																			
218			9																						
219		49																							
220					57																				
221																									
222																									
223																									
224																									
225																									
226																									
227																									
228																									
229																									
230																									
231																									
232																									
233																									
234																									
235																									
236																									
237																									
238																									
239																									
240																									
241																									
242																									
243																									
244																									
245																									
246																									
247																									
248																									
249																									
250																									
251																									






	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE	 XXXXXXXXXX						
Document Title	DOCUMENT No							Page 109 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure AVIII.2 Fault location of the phases R and T windings



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 110 of 121
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX VIII

WEATHER CONDITION

The weather condition and the lightning strikes possibility are investigated as the followings:

Figure VIII.1 shows the weather condition obtained from Xian Weather Organization in that particular date (in Persian).

An investigation shows that the phase S of the X-Y 400KV line surge arrester counts a lightning discharge. The discharge had been happened between 16.1.86 till 12.6.86 (Persian dates)

The phase S of the generator no. 8 surge arrester counter shows three lightning discharges. The discharge had been happened between 15.2.86 till 15.4.86 (Persian dates)

Unit 7 arresters not recorded any discharges.

Considering the 300MVA 400KV/15.75KV YNd11 shown in Figure VIII.2, the phase S in 400KV is mutual coupled with RT winding in 15.75KV section. Phase S of the primary has a direct coupling with phase T of the secondary.



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title		DOCUMENT No					
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure VIII.1 weather condition (written in Persian)

شماره: ۸۶/۸/۱۳
تاریخ: ۸۶/۸/۲۲

باسمه تعالی

جناب آقای مهندس کریمی
سرپرست محترم طرح کارون ۳

احتراماً بازگشت به دورنگار شماره ۷/۲۵۹۷/۲ مورخ ۸۶/۸/۲۰ در خصوص درخواست اطلاعات هواشناسی مورد نیاز، طبق گزارش ایستگاههای هواشناسی سینوپتیک نزدیک به مسیر اعلام شده در مورخ ۸۶/۳/۶ به شرح جدول پیوست میباشد. مع الوصف علیرقم پدیده رعد و برق در میدان عمل ایستگاههای پدیده شده با توجه به نوع ایر گزارش شده، وقوع صاعقه در ارتفاعات استان از احتمال بالایی برخوردار می باشد. %

سهرداد نظره سامانی
مدیرکل هواشناسی استان

تاریخ: ۸۶/۸/۲۲
شماره: ۸۶-۲۵۹۷
پیوست: ۱

بسمه تعالی


اداره کل هواشناسی خوزستان



سرپرست طرح کارون ۳
سلام حبیبکم

احتراماً بازگشت به نامه شماره ۷/۲۵۹۷/۳ مورخ ۸۶/۸/۱۳ نزدیکترین ایستگاه هواشناسی به سد کارون ۳، شهرستان ایذه می باشد که با استناد به اطلاعات ثبت شده هواشناسی هیچگونه پدیده قابل ملاحظه ای در تاریخ فوق به وقوع نپیوسته ولی در تاریخ ۸۶/۳/۷ در ایستگاه ایذه مقدار ۳۰ آسمان ابر کومولوس نوع ۲ گزارش گردیده و با توجه به موقعیت سد کارون ۳، منطقه فوق احتمال وقوع رعد و برق در ارتفاعات دور از انظار نمی باشد، مراتب جهت اطلاع ارسال می گردد.

نام: شمس خدائی
سرپرست اداره کل هواشناسی خوزستان

Figure VIII.2 300MVA 400/15.75KV YNd11 TRANSFORMER CONNECTION ON UNIT 7 Coupling capacitor is 2.6 nF per phase.



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

APPENDIX X

PROTECTION RESPONSE

The protection equipments response during the events, are represented in table AX.1. The event lists shows the events occurred for the four relays, REGA, REGB, REL87, and RET87.

X.1 Fault flows

Having known that an internal LLG fault has occurred inside the generator, the followings are the magnitude of the fault flows of the above relays for this fault:

Relay REGA, and REGB:

The fault currents and the differential magnitude of the faults are shown in appendix III which agrees with what is announcing by this relay.

Relay REL87:

The amount of current paths this relay according to the fault analysis is 2653 A. This is $2653 \times 2 / 2000 \text{ IN} = 2.653 \text{ IN}$ according to the relay differential settings. The stabilizing signals of this relay response for 1.5IN. Therefore, it sees the internal fault of generator and acts accordingly. The Definite time has also seen the events and acts accordingly. The relay gets off when the phase T has been opened by GCB.

The setting of this relay is shown in figure AX.1



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

Figure AX.1 settings of REL87

```

ABB Power Automation Ltd      KARUN GSU 1,2      REL316*4 - Line Terminal
Edit Function Parameters
Func Nr 1 - Diff-Line          * Line Diff. 87LA *
ParSet4..1                    P1                      Select
Trip                          B12340000
g                              0.50                    IN
v                              0.50                    IN
b                              1.50                    IN
g-High                        2.00                    IN
I-Inst                        10                      IN
InrushRatio                   10                      %
InrushTime                    0                       s
a1                             2.00
s1                             D                        Select
CurrentInp1                   1                       AnalogAddr
a2                             2.00
more...

```

```



ABB Power Automation Ltd      KARUN GSU 1,2      REL316*4 - Line Terminal
Edit Function Parameters
Func Nr 2 - Current-DT        * *
ParSet4..1                    P1                      Select
Trip                          B12340000
Delay                          01.00                   s
I-Setting                     00.56                   IN
MaxMin                        Max-Inrush              Select
NrOfPhases                    003
CurrentInp                    1                       AnalogAddr
BlockInp                      F                        BinaryAddr
Trip                          S110 L10 ER             SignalAddr
Start                          ER                        SignalAddr
RETURN/ENTER

```

```

ABB Power Automation Ltd      KARUN GSU 1,2      REL316*4 - Line Terminal
Edit Function Parameters
Func Nr 3 - Current-Inv      * *
ParSet4..1                    P1                      Select
Trip                          B12340000
c-Setting                     2.00                    Select
k1-Setting                    000.01                  s
I-Start                       4.00                    IB
t-min                         00.0                    s
NrOfPhases                    3
CurrentInp                    1                       AnalogAddr
IB-Setting                    2.50                    IN
BlockInp                      F                        BinaryAddr
Trip                          S109 L09 ER             SignalAddr
Start                          ER                        SignalAddr
RETURN/ENTER

```

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 114 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Relay RET316*4:

The amount of current paths this relay according to fault analysis is 2653 A in HV side, 2856 A for GSU1 and 439 A in GSU2. The stabilizing signal is $SQRT(2856^2 + 439^2) = 2971A * 2/2000 = 2.97 IN$. It produces 296 A differentials in phase S, 311 A in phase T and 293 A in phase R. The differential settings see these amount of current as $296^2/2000=0.3IN$ in phase S, $311^2/2000=0.3IN$ in phase T and $293^2/2000=0.3IN$ in phase R (the calculation are made using with PASHA protection system analysis not reported here). The relay settings are shown in figure AX.2. The stabilizing will prevent the differential to operate. The function of this relay during the fault is more or less as the response of REL316*4.

X.1 Event list sequences

According to what are described in this document, the sequences of the protection system function according to the approximate time of the events are listed in table AX.1.



	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	Page 115 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Figure AX.2 settings of RET87

```



ABB Power Automation Ltd      KARUN GSU 1,2      RET316*4 Transformer Terminal
Edit Function Parameters
-----
Func Nr 1 - Diff-Transf      * HU Busduct Diff-Prot *
ParSet4..1                  P1                      Select
Trip                        B12345678
g                            0.20                    IN
v                            0.50
b                            1.50
g-High                       2.00                    IN
I-Inst                       10                      IN
InrushRatio                  10                      %
InrushTime                   5                        s
a1                           2.00
s1                            D                        Select
CurrentInp1                  1                        AnalogAddr
a2                           2.00
more...

```

```

ABB Power Automation Ltd      KARUN GSU 1,2      RET316*4 Transformer Terminal
Edit Function Parameters
-----
Func Nr 2 - Current-DT      * CURRENT-DT-LINE *
ParSet4..1                  P1                      Select
Trip                        B12345678
Delay                        00.02                  1.3                    s
I-Setting                   00.56                  0.563                  IN
MaxMin                       Max-Inrush             Select
NrOfPhases                   003
CurrentInp                    4                      AnalogAddr
BlockInp                     F                      BinaryAddr
Trip                          L07 ER                 SignalAddr
Start                         ER                      SignalAddr
RETURN/ENTER

```

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	Page 116 of 121
	IWPRD	01	0001	EL	ST	001	D1	

```



ABB Power Automation Ltd      KARUN GSU 1,2      RET316*4 Transformer Terminal
Edit Function Parameters
Func Nr 3 - Current-Inv INST      * CURRENT-INV-LINE *
ParSet4..1      P1      Select
Trip      B12345678
c-Setting      2.00      Select
k1-Setting      000.01 changed      s
I-Start      4.00      IB
t-min      00.0      s
NrOfPhases      3
CurrentInp      4      AnalogAddr
IB-Setting      2.50      IN
BlockInp      F      BinaryAddr
Trip      L08 ER      SignalAddr
Start      ER      SignalAddr
RETURN/ENTER

```

```

ABB Power Automation Ltd      KARUN GSU 1,2      RET316*4 Transformer Terminal
Edit Function Parameters
Func Nr 5 - Current-DT      * CURRENT-DT-GSU-1 *
ParSet4..1      P1      Select
Trip      B12345678
Delay      00.02 1.1      s
I-Setting      00.28 0.282      IN
MaxMin      Max-Inrush      Select
NrOfPhases      003
CurrentInp      1      AnalogAddr
BlockInp      F      BinaryAddr
Trip      L09 ER      SignalAddr
Start      ER      SignalAddr
RETURN/ENTER

```

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	Page 117 of 121
	IWPRD	01	0001	EL	ST	001	D1	

```

ABB Power Automation Ltd      KARUN GSU 1,2      RET316*4 Transformer Terminal
Edit Function Parameters
Func Nr 6 - Current-Inv INST      * CURRENT-INV-GSU-1 *
ParSet4..1      P1      Select
Trip      B12345678
c-Setting      2.00      Select
k1-Setting      000.01      s
I-Start      2.00      IB
t-min      00.0      s
NrOfPhases      3
CurrentInp      1      AnalogAddr
IB-Setting      2.50      IN
BlockInp      F      BinaryAddr
Trip      L10 ER      SignalAddr
Start      ER      SignalAddr
RETURN/ENTER

```







	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/UNIT	DIS	DOC	SEQ	REV	Page 118 of 121
	IWPRD	01	0001	EL	ST	001	D1	

Table AX.1 Event lists



U7-RELGA							Time of event Announced Occurrence	
32193	04:43;07.436	GenStart			OFF			
32194	11:04;25.166	GenStart			ON			
32195	00:00;00.000	44 64GB Gen.Busbar E/F	Start		ON	0	0	
32196	00:00;00.003	GenTrip			ON			
32197	00:00;00.003	GenTripMem			ON			
32198	00:00;00.003	37 87G Gen. Differential	Trip		ON	3	3	
32199	00:00;00.006	32 Delay for 50BF	Start		ON	6	3	
32200	00:00;00.020	37 87G Gen. Differential				20	3	
		10.54 IN (Id-R)						
32201	00:00;00.020	42 27 Gen. Undervoltage	Start		ON	20	3	
32202	00:00;00.023	37 87G Gen. Differential				23	3	
		10.62 IN (Id-T)						
32203	00:00;00.036	Bin.Inp. Nr.14/11 (N/A-TCS)			ON	36	3	
32204	00:00;00.043	37 87G Gen. Differential				43	3	
		0.34 IN (Id-S)						
32205	00:00;00.070	24 40 Integrator	Start		ON	70	56	
32206	00:00;00.080	Bin.Inp. Nr.15/ 4 (Generator C.B. is open)			ON	80	65	
32207	00:00;00.080	12 GCB/DS is open	BinOutput		ON	80	65	
32208	00:00;00.080	17 f11orf12orf13orf28	BinOutput		ON	80	65	
32209	00:00;00.081	41 DisturbanceR	BinOutput		ON	81	65	
32210	00:00;00.100	42 27 Gen. Undervoltage	Start		OFF	100	65	
32211	00:00;00.133	Bin.Inp. Nr.14/ 2 (Excitation external tr)			ON	133	100	
32212	00:00;00.136	2 Excitation ext. trip	BinOutput		ON	136	100	
U7-RELGB								
38014	11:07;31.711	GenStart			ON			
38015	00:00;00.000	GenStartMem			ON			
38016	00:00;00.000	30 49S Stator overload	Start		ON	4	2	
38017	00:00;00.003	40 64S(1)95%St.E/F-CBopen	Start		ON	7	2	
38018	00:00;00.006	45 50S Gen. Interturn	Start		ON	10	3	
38019	00:00;00.016	26 21G(1)Zmin.(GCBclosed)	Start		ON	20	3	
38020	00:00;00.016	27 21G(2)Zmin/CBcl.+open	Start		ON	20	3	

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 119 of 121
	IWPRD	01	0001	EL	ST	001	D1	

38021	00:00;00.016	29 46.2	Start			ON	20	3
38022	00:00;00.023	36 51ET Excit.Tr.O/C Inv.	Start			ON	27	3
38023	00:00;00.026	38 51V(1) (Gen.CB closed)	Start			ON	30	3
38024	00:00;00.026	39 51V(2) GenCB Cl.ropen	Start			ON	30	3
38025	00:00;00.033	Bin.Inp. Nr.14/11 (N/A-TCS)				ON	36	33
38026	00:00;00.076	Bin.Inp. Nr.15/ 4 (Generator C.B. is open)				ON	80	65
38027	00:00;00.076	12 GCB/DS is open	BinOutput			ON	80	65
38028	00:00;00.076	18 f12 or f13	BinOutput			ON	80	65
38029	00:00;00.076	19 f12 or f17	BinOutput			ON	80	65
38030	00:00;00.076	20 f11orf12orf46	BinOutput			ON	80	65
38031	00:00;00.080	26 21G(1)Zmin.(GCBclosed)	Start			OFF	84	69
38032	00:00;00.090	38 51V(1) (Gen.CB closed)	Start			OFF	94	79
38033	00:00;00.130	Bin.Inp. Nr.14/ 2 (Excitation external tr)				ON	134	100
38034	00:00;00.130	GenTrip				ON		
38035	00:00;00.130	GenTripMem				ON		
38036	00:00;00.130	2 Excitation ext. trip	BinOutput			ON	134	100
38037	00:00;00.130	31 Delay for 50BF	Start			ON	134	100
REL								
6192	15:31;31.206	1 Line Diff. 87LA	Stabilizing			ON	10	3
6193	15:31;31.213	GenStart				ON		
6194	00:00;00.000	2 Current-DT	Start			ON	17	3
6195	00:00;00.040	1 Line Diff. 87LA	Stabilizing			OFF	71	67
6196	00:00;00.041	2 Current-DT	Start			OFF	72	67
RET								
13471	15:29;16.535	1 HV Busduct Diff-Prot	Stabilizing			ON	due to calc.22	3
13472	15:29;16.535	GenStart				ON		
13473	00:00;00.000	5 CURRENT-DT-GSU-1	Start			ON	gen8 22	3
13474	00:00;00.010	2 CURRENT-DT-LINE	Start			ON	32	3
13475	00:00;00.045	2 CURRENT-DT-LINE	Start			OFF	67	67
13476	00:00;00.050	5 CURRENT-DT-GSU-1	Start			OFF	72	67
13477	15:29;16.585	GenStart						

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
	Document Title	DOCUMENT No						
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	Page 120 of 121
	IWPRD	01	0001	EL	ST	001	D1	

					OFF		
13478	15:29;16.588	1 HV Busduct Diff-Prot	Stabilizing		OFF	75	67

	X III HYDRO POWER GENERATION PLANT UNIT 7 GENERATOR DAMAGE							 XXXXXXXXXX
Document Title	DOCUMENT No							Page 121 of 121
CAUSES OF THE DAMAGE	PHASE	AREA	TRAIN/ UNIT	DIS	DOC	SEQ	REV	
	IWPRD	01	0001	EL	ST	001	D1	

References:

- [1] Allan Greenwood, "Electrical Transients in Power systems", John Wiley & Sons, Inc. Press
- [2] Donald Beeman, "Industrial Power System Handbook", McGraw-Hill Book Company press
- [3] Shott, H.S., and H. Peterson, "Criteria for Neutral Stability of Wye-Grounded Primary Broken Delta Secondary Transformer Circuits", AIEE Transactions on Power Systems, vol. 60, Nov. 1941
- [4] D.A.N. Jacobson, R.W. Menzies, "Investigation of Station Service Transformer Ferroresonance in Manitoba Hydro's 230-KV Doresey Converter Station", IPST,2001 – International Conference on Power Systems Transients, Rio de Janeiro, June 24-28, 2001
- [5] Foad & Anderson, "Power System Dynamics", John Wiley & Sons, Inc. Press